

DYNAMIC ENGINEERING CONSULTANT CO., LTD.

Column Whit Axial Force and Moment X - X

(Ultimate Stress Design method in accordance with ACI 318)

Job No. : 193018

Rev. : 0

Initial : CKJ


Date : 12-Nov-20

Column No. CT-1 Roof FL.

Project : อาคารทิศตะวันออก


filename : COLUMN

Concrete Strength	f_c'	=	350	[kg/cm ²]
	f_y SD	=	4000	[kg/cm ²]
	f_y RD	=	2400	[kg/cm ²]
Column Dimension	b	=	40	[cm]
	h	=	40	[cm]
	d'	=	4	[cm]
	d''	=	4	[cm]
Load	ϕP_n	=	5	[T]
Moment	ϕM_n	=	1	[T-m]
Separate Steel 2 group	1 st.	=	8	$A_s = 16.1$ [cm ²]
	2 nd.	=	4	$A_s = 8.0$ [cm ²]
Steel Reinforcement	No.	=	12	
	d	=	36	[cm]
	C_b	=	21.771	[cm]
	p of Steel	=	0.015	OK
Main Steel Used	12 DB 16		DB 16	
Stirrup	RB 9 @ 0.250		RB 9	
e/b	=	0.15		[cm]




Column (40 x 40)
Steel 12 DB 16
Stirrup RB 9 @ 0.250

— Boundary of tie stirrup Column
— Boundary of spiral stirrup Column
— Boundary of Ultimate Capacity



Column CT-1 (40 x 40)



DYNAMIC ENGINEERING CONSULTANT CO., LTD.

Column Whit Axial Force and Moment X - X

(Ultimate Stress Design method in accordance with ACI 318-89)

Job No. : 193018

Rev.	:	0
------	---	---

Initial : CK


Date : 12-Nov-20

Column No. C-X

Project : อาคารหิศตะวันออก


```
filename : COLUMN
```

Concrete Strength	$f_c' =$	350	[kg/cm ²]
	f_y SD =	4000	[kg/cm ²]
	f_y RD =	2400	[kg/cm ²]
Column Dimension	$b =$	20	[cm]
	$h =$	20	[cm]
	$d' =$	4	[cm]
	$d'' =$	4	[cm]
Load	$\phi P_n =$	10	[T]
Moment	$\phi M_n =$	1	[T-m]
Separate Steel 2 group	1 st. =	4	As = 8.0 [cm ²]
	2 nd. =	0	As = 0.0 [cm ²]
Steel Reinforcement	No. =	4	
	$d =$	16	[cm]
$d(e_u / (e_y + e_u))$	$C_b =$	9.676	[cm]
	ρ of Steel =	0.020	OK
Main Steel Used	4 DB 16		
Stirrup	RB 9 @		
$e_b =$	0.10	[cm]	




Column (20 x 20)
Steel 4 DB 16
Stirrup RB 9 @ 0.150

- Boundary of tie stirrup Column
- Boundary of spiral stirrup Column
- Boundary of Ultimate Capacity



Column C-X (20 x 20)






รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

3. รายการคำนวณพื้นที่คอนกรีต อัดแรงภายหลัง





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารที่สะดวกวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION STRUCTURAL CONCRETE SOFTWARE SYSTEM 1733 Woodside Road, Suite 220, Redwood City, California 94061
ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN Version 7.10 AMERICAN (ACI 318-99/UBC-77) ADAPT CORPORATION - Structural Concrete Software System 1733 Woodside Road, Suite 220, Redwood City, California 94061 Phone: (650)306-2400, Fax: (650)364-4678 Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 11, 2020 At Time: 10:4
PROJECT FILE: FL2-CH

PROJECT TITLE:
Government Complex
FL2-CH

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS	350.00 Kg/cm ²
for COLUMNS	350.00 Kg/cm ²
MODULUS OF ELASTICITY for BEAMS/SLABS	287.00 T/cm ²
for COLUMNS	287.00 T/cm ²
CREEP factor for deflections for BEAMS/SLABS	2.00
CONCRETE WEIGHT	NORMAL
SELF WEIGHT	2400.00 Kg/m ³

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top	1.590
At Bottom	1.590

COMPRESSION STRESS limits (multiple of (f'c))

At all locations	.450
------------------------	------

REINFORCEMENT:

YIELD Strength	4.00 T/cm ²
Minimum Cover at TOP	1.50 cm
Minimum Cover at BOTTOM	1.50 cm

POST-TENSIONING:

SYSTEM	BONDED
Ultimate strength of strand	19.00 T/cm ²
Average effective stress in strand (final)	10.80 T/cm ²
Strand area.....	.990 cm ²
Min CGS of tendon from TOP.....	4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans..	5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans..	5.60 cm
Min average precompression	10.00 Kg/cm ²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system ... (using EQUIVALENT FRAME) TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S T F					TOP	BOTTOM/MIDDLE						
P Y O					FLANGE	FLANGE						
A P R	LENGTH	WIDTH	DEPTH		width thick.	width thick.	HEIGHT					
N E M	m	cm	cm		cm	cm	cm					
1-2-3	4	5	6	7	8	9	10	11	12	13		
C U 1	3.55	450.00	23.00					.00	.90	.10		
1 U 1	8.40	450.00	23.00					.00	.90	.10		
2 U 1	8.40	450.00	23.00					.00	.90	.10		
3 U 1	8.40	450.00	23.00					.00	.90	.10		
4 U 1	8.40	450.00	23.00					.00	.90	.10		
5 U 1	8.40	450.00	23.00					.00	.90	.10		
C U 1	2.80	450.00	23.00					.00	.90	.10		

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line



2.2 - SUPPORT WIDTH AND COLUMN DATA

	SUPPORT		LOWER COLUMN			UPPER COLUMN			
JOINT	WIDTH	LENGTH	B (DIA)	D	CBC*	LENGTH	B (DIA)	D	CBC*
	cm	m	cm	cm		m	cm	cm	
1	2	3	4	5	6	7	8	9	10
1	80.00	4.30	100.00	80.00	(1)	3.60	100.00	80.00	(1)
2	80.00	4.30	100.00	80.00	(1)	3.60	100.00	80.00	(1)
3	100.00	4.30	100.00	80.00	(1)	3.60	100.00	80.00	(1)
4	100.00	4.30	100.00	80.00	(1)	3.60	100.00	80.00	(1)
5	100.00	4.30	100.00	80.00	(1)	3.60	100.00	80.00	(1)



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 3
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

6 100.00 4.30 100.00 80.00 (1) 3.60 100.00 80.00 (1)

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3

Fixed at near end, roller with rotational fixity at far end .. = 4

3 - INPUT APPLIED LOADING

<---CLASS--->

D = DEAD LOAD

L = LIVE LOAD

<-----TYPE----->

U = UNIFORM

P = PARTIAL UNIFORM

C = CONCENTRATED

M = APPLIED MOMENT

Li = LINE LOAD

SW= SELF WEIGHT Computed from geometry input and treated as dead loading

Unit selfweight W = 2400.0 Kg/m³

SPAN	CLASS	TYPE	Intensity T/m^2	(From ... (m	To) m)	(M or C ...At) (T-m or T ...m)	Total on Trib T/m	
-1-	2-	3-	4-	5-	6-	7-	8-	9-
CANT	L	U	.300	.00	3.55			1.350
CANT	D	U	.370	.00	3.55			1.665
CANT	SW	U		.00	3.55			2.484
1	L	U	.300	.00	8.40			1.350
1	D	U	.370	.00	8.40			1.665
1	SW	U		.00	8.40			2.484
2	L	U	.300	.00	8.40			1.350
2	D	U	.370	.00	8.40			1.665
2	SW	U		.00	8.40			2.484
3	L	U	.300	.00	8.40			1.350
3	D	U	.370	.00	8.40			1.665
3	SW	U		.00	8.40			2.484
4	L	U	.300	.00	8.40			1.350
4	D	U	.370	.00	8.40			1.665
4	SW	U		.00	8.40			2.484
5	L	U	.300	.00	8.40			1.350
5	D	U	.370	.00	8.40			1.665
5	SW	U		.00	8.40			2.484
CANT	L	U	.300	.00	2.80			1.350
CANT	D	U	.370	.00	2.80			1.665
CANT	SW	U		.00	2.80			2.484







รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 4
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

SPAN	CLASS	TYPE	UNIFORM		(CON. or PART.)		(M O M E N T)	
			LINE (T/m)	(T/m^2)	(T@m or m-m)	(T-m @ m)	(T-m @ m)	(T-m @ m)
-1	-2	-3	-4	-5	-6	-7	-8	-9
CANT	L	U	.300					
CANT	D	U	.370					
1	L	U	.300					
1	D	U	.370					
2	L	U	.300					
2	D	U	.370					
3	L	U	.300					
3	D	U	.370					
4	L	U	.300					
4	D	U	.370					
5	L	U	.300					
5	D	U	.370					
CANT	L	U	.300					
CANT	D	U	.370					

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75



4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA	I	Yb	Yt
	cm^2	cm^4	cm	cm
-1	-2	-3	-4	-5
CANT.	10350.00	.4563E+06	11.50	11.50
1	10350.00	.4563E+06	11.50	11.50
2	10350.00	.4563E+06	11.50	11.50
3	10350.00	.4563E+06	11.50	11.50
4	10350.00	.4563E+06	11.50	11.50
5	10350.00	.4563E+06	11.50	11.50
CANT.	10350.00	.4563E+06	11.50	11.50

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2

5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >		
SPAN	M(l) *	Midspan	M(r) *	SH(l)	SH(r)
-1-----2-		-3-----	-4-----	-5-----	-6-----
CANT	----	-----	-26.14	----	14.73
1	-24.42	12.20	-24.36	-17.43	17.42
2	-24.38	12.21	-24.38	-17.43	17.43
3	-24.38	12.21	-24.38	-17.43	17.43
4	-24.38	12.21	-24.38	-17.43	17.43
5	-24.48	12.26	-24.18	-17.46	17.39
CANT	-16.26	-----	-----	-11.62	-----

Note:

* = Centerline moments

< 5.3 REACTIONS (T) >		< 5.4 COLUMN MOMENTS (Tm) >	
JOINT	2	Lower columns	Upper columns
1	32.16	.80	.92
2	34.84	-.01	-.01
3	34.85	.00	.00
4	34.85	.00	.00
5	34.89	-.04	-.05
6	29.01	3.70	4.22



6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->

<----- left* ----->		<----- midspan ----->		<----- right* ----->		<--SHEAR FORCE-->		
SPAN	max	min	max	min	max	min	left	right
-1-----2-----								
-3-----4-----5-----6-----7-----8-----9-----								
CL	-----		-----		-8.51		-----	4.79
1	-7.95	-.08	3.97	-.08	-7.93	-.06	-5.67	5.67
2	-7.93	-.07	3.97	-.07	-7.93	-.07	-5.67	5.67
3	-7.93	-.07	3.97	-.07	-7.93	-.07	-5.67	5.67
4	-7.93	-.07	3.97	-.07	-7.93	-.07	-5.67	5.67
5	-7.96	-.09	3.99	-.06	-7.87	-.03	-5.68	5.66
CR	-5.29		-----		-----		-3.78	-----

Note:

* = Centerline moments

<- 6.2 REACTIONS (T) ->			<- 6.3 COLUMN MOMENTS (Tm) ->			
			<--- LOWER COLUMN --->		<--- UPPER COLUMN --->	
JOINT	max	min	max	min	max	min
-1-	-2-	-3-	-4-	-5-	-6-	-7-
1	10.50	4.80	3.92	-3.66	4.47	-4.17



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 6
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

2	11.41	5.63	3.62	-3.62	4.12	-4.13
3	11.41	5.64	3.62	-3.62	4.12	-4.12
4	11.41	5.64	3.62	-3.62	4.12	-4.12
5	11.41	5.65	3.60	-3.62	4.11	-4.12
6	9.47	3.77	3.66	-2.46	4.17	-2.80

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases

7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D DEAD LOAD MOMENTS (Tm)

SPAN	<- left* ->	<- midspan ->	<- right* ->
-1-	-2-	-3-	-4-
CANT	-----	-----	-20.58
1	-17.78	12.20	-17.72
2	-17.74	12.21	-16.19
3	-16.19	12.21	-16.19
4	-16.19	12.21	-16.19
5	-16.27	12.26	-16.01
CANT	-10.97	-----	-----

Note:

* = face-of-support



7.2 R E D U C E D LIVE LOAD MOMENTS (Tm)

SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
-1-	-2-	-3-	-4-	-5-	-6-	-7-
CL	-----	-----	-----	-----	-6.70	-----
1	-5.79	-.08	3.97	-.08	-5.77	-.07
2	-5.77	-.07	3.97	-.07	-5.27	-.07
3	-5.27	-.07	3.97	-.07	-5.27	-.07
4	-5.27	-.07	3.97	-.07	-5.27	-.07
5	-5.29	-.09	3.99	-.06	-5.21	-.03
CR	-3.57	-----	-----	-----	-----	-----

Note:

* = face-of-support

8 - S U M O F DEAD AND LIVE MOMENTS (Tm)

Maxima of dead load and live load span moments combined
for serviceability checks (1.00DL + 1.00LL)

<----- left* -----> <----- midspan -----> <----- right* ----->



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 7
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

SPAN	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
CL	-----		-----		-27.28	
1	-23.57	-17.86	16.17	12.12	-23.49	-17.79
2	-23.51	-17.81	16.18	12.14	-21.46	-16.26
3	-21.46	-16.26	16.18	12.14	-21.46	-16.26
4	-21.46	-16.26	16.18	12.14	-21.46	-16.26
5	-21.56	-16.36	16.25	12.20	-21.22	-16.04
CR	-14.54		-----		-----	

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:

For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	TENDON	PROFILE			
	TYPE	X1/L	X2/L	X3/L	A/L
-----1-----2-----3-----4-----5-----					
CANT	1			.000	
1	1	.100	.500	.100	.000
2	1	.100	.500	.100	.000
3	1	.100	.500	.100	.000
4	1	.100	.500	.100	.000
5	1	.100	.500	.100	.000
CANT	1	.100			



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION

<----- SELECTED VALUES ----->					<--- CALCULATED VALUES --->		
FORCE		<- DISTANCE OF CGS (cm) ->			P/A	Wbal	Wbal
SPAN	(T/-)	Left	Center	Right	(Kg/cm^2)	(T/-)	(%DL)
--1-----2-----3-----4-----5-----6-----7-----8--							



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 8
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

CANT	212.283	-11.50		-4.20	20.78	2.491	60
1	217.759	-4.20	-9.40	-5.20	21.04	1.160	28
2	149.672	-5.20	-17.40	-4.20	14.46	2.155	52
3	142.305	-4.20	-17.40	-4.20	13.75	2.130	51
4	145.344	-4.20	-17.40	-4.20	14.04	2.175	52
5	144.370	-4.20	-17.40	-4.20	13.95	2.161	52
CANT	137.792	-4.20		-11.50	13.60	2.621	63

Approximate weight of strand 528.5 Kg

9.35 - TENDON SELECTION DATA:

TYPE	SEL.	FORCE (T)	TENDON EXTENTS							
			<C>	<1>	<2>	<3>	<4>	<5>	<C>	
-1	-2	-3								
A	12	12.06	=====							
B	6	12.04	=====							

9.5 REQUIRED MINIMUM POST - TENSIONING FORCES (T)

SPAN	<- BASED ON STRESS CONDITIONS ->			<- BASED ON MINIMUM P/A ->		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
-1	-2	-3	-4	-5	-6	-7
CANT	-----	-----	161.37	-----	-----	103.50
1	178.57	77.13	184.35	103.50	103.50	103.50
2	124.45	47.01	85.73	103.50	103.50	103.50
3	88.29	47.77	87.28	103.50	103.50	103.50
4	88.29	48.12	90.12	103.50	103.50	103.50
5	90.82	48.78	85.96	103.50	103.50	103.50
CANT	31.03	-----	-----	103.50	-----	-----

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

	LEFT *				RIGHT *			
	TOP		BOTTOM		TOP		BOTTOM	
	max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
-1	-2	-3	-4	-5	-6	-7	-8	-9
CL	-----	-----	-----	-----	17.02	-----	-----	-58.38
1	23.39	-----	-----	-65.29	23.58	-----	-----	-66.66
2	6.40	-7.97	-----	-49.47	12.34	-.76	-----	-40.71
3	14.29	-----	-----	-42.19	15.02	-----	-----	-42.09
4	14.68	-----	-----	-42.31	14.24	-----	-----	-42.75
5	14.65	-----	-----	-42.97	14.46	-----	-----	-41.77
CR	5.78	-3.22	-----	-32.59	-----	-----	-----	-----

Note:

* = face-of-support





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 9
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

	C E N T E R			
	TOP		BOTTOM	
	max-T	max-C	max-T	max-C
-1-----2-----3-----4-----5-----				
CL	-----	-----	-----	-----
1	-----	-51.74	9.66	-.53
2	-----	-34.53	5.61	-4.59
3	-----	-35.37	7.87	-2.33
4	-----	-35.50	7.41	-2.79
5	-----	-35.66	7.76	-2.45
CR	-----	-----	-----	-----

9.7 POST-TENSIONING B A L A N C E D M O M E N T S , S H E A R S & R E A C T I O N S

SPAN	<-- S P A N M O M E N T S (Tm) -->			<-- SPAN SHEARS (T) -->	
	left*	midspan	right*	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----					
CANT	-----	-----	12.32	-----	7.60
1	5.97	-3.99	5.59	-.22	-.22
2	12.43	-8.22	10.93	-.22	-.22
3	10.25	-7.61	10.13	-.02	-.02
4	10.15	-7.67	10.15	.00	.00
5	10.13	-7.64	10.06	.00	.00
CANT	6.93	-----	-----	5.93	-----

Note:

* = face-of-support

joint	<--REACTIONS (T)-->		<-- COLUMN MOMENTS (Tm) -->	
			Lower columns	Upper columns
1	.223		-4.254	-4.846
2	-.006		3.425	3.901
3	-.195		-.384	-.438
4	-.022		.010	.012
5	-.001		-.010	-.011
6	.001		-.655	-.746



10 - F A C T O R E D M O M E N T S & R E A C T I O N S

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 10
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

-1-	-2-	-3-	-4-	-5-	-6-	-7-
CL	-----		-----		-40.20	
1	-43.74	-34.05	15.67	8.79	-41.93	-32.24
2	-34.47	-24.78	24.86	17.98	-29.81	-20.98
3	-30.51	-21.68	25.10	18.22	-30.23	-21.40
4	-30.19	-21.36	25.28	18.40	-30.19	-21.36
5	-30.37	-21.52	25.36	18.47	-29.87	-21.06
CR	-21.43		-----		-----	

Note:

* = face-of-support

10.2 SECONDARY MOMENTS (Tm)

SPAN	<-- left* -->	<- midspan ->	<-- right* -->
-1-	-----	-----	-----
1	-9.01	-8.16	-7.32
2	.18	1.01	1.81
3	1.11	1.25	1.39
4	1.43	1.43	1.43
5	1.41	1.40	1.40

Note:

* = face-of-support



10.3 FACTORED REACTIONS (T)

JOINT	max	min	max	min	max	min
-1-	-----	-----	-----	-----	-----	-----
1	63.10	53.40	3.54	-9.35	4.03	-10.65
2	68.17	58.34	9.56	-2.75	10.89	-3.13
3	67.99	58.18	5.77	-6.53	6.57	-7.44
4	68.17	58.35	6.16	-6.14	7.02	-6.99
5	68.24	58.45	6.06	-6.22	6.90	-7.09
6	56.72	47.02	10.75	.35	12.25	.40

10.4 FACTORED COLUMN MOMENTS (Tm)

<-- LOWER column --> <-- UPPER column -->

JOINT	max	min	max	min	max	min
-1-	-2-	-3-	-4-	-5-	-6-	-7-
1	63.10	53.40	3.54	-9.35	4.03	-10.65
2	68.17	58.34	9.56	-2.75	10.89	-3.13
3	67.99	58.18	5.77	-6.53	6.57	-7.44
4	68.17	58.35	6.16	-6.14	7.02	-6.99
5	68.24	58.45	6.06	-6.22	6.90	-7.09
6	56.72	47.02	10.75	.35	12.25	.40

11 - M I L D S T E E L

Support cut-off length for minimum steel (length/span)17
Span cut-off length for minimum steel (length/span)33
Top bar extension beyond where required 30.00 cm
Bottom bar extension beyond where required 30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1 TOTAL WEIGHT OF REBAR = .0 Kg AVERAGE = .0 Kg/m²
TOTAL AREA COVERED = 217.57 m²

11.2.1 STEEL AT MID - SPAN

SPAN	T O P					B O T T O M				
	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	----	TENS----->			<---ULT---	----	TENS----->	
--1----	2-----	3-----	4-----	5-----		6-----	7-----	8-----	9-----	
1	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
2	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
4	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
5	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.3.1 STEEL AT SUPPORTS

JOINT	T O P					B O T T O M				
	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	----	MIN----->			<---ULT---	----	MIN----->	
--1----	2-----	3-----	4-----	5-----		6-----	7-----	8-----	9-----	
1	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
2	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
4	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
5	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
6	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]	AREA [cm ²]
--1----	2-----	3-----	4-----	5-----	6-----	7-----

Notes:

Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.
Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.

11.5.1 ARRANGEMENT OF TOP BARS

T O P S T E E L					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
--1----	2-----	3-----	4-----	5-----	6-----

11.5.2 ARRANGEMENT OF BOTTOM BARS

B O T T O M S T E E L					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
--1----	2-----	3-----	4-----	5-----	6-----

12 - P U N C H I N G S H E A R C H E C K





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 12
ACI-99

(FL2-CH)

ADAPT-PT V- 7.10

LEGEND:

CONDITION... 1 = INTERIOR COLUMN
2 = END COLUMN
3 = CORNER COLUMN
4 = EDGE COLUMN (PARALLEL TO SPAN)
5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
PERFORM SHEAR CHECK MANUALLY
6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR

CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)
2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

JNT	COND.	FACTORED ACTIONS		<- PUNCHING SHEAR STRESSES IN Kg/cm ² ->		TOTAL	allow- able	STRESS RATIO	CASE
		shear T	moment T-m	due to shear	due to moment				
-1-	2-	3-	4-	5-	6-	7-	8-	9-	10-
1	4	63.10	20.01	9.91	3.07	12.98	16.56	.78	1
2	4	68.17	20.46	10.70	3.14	13.84	16.56	.84	1
3	4	67.99	13.98	10.68	2.14	12.82	16.56	.77	1
4	4	68.17	13.18	10.70	2.02	12.73	16.56	.77	1
5	4	68.24	13.31	10.72	2.04	12.76	16.56	.77	1
6	4	56.72	23.00	8.91	3.53	12.44	16.56	.75	1

PUNCHING SHEAR CHECK SATISFACTORY
NO ADDITIONAL REBAR OR CHANGE IN SECTION IS NECESSARY

13 - MAXIMUM SPAN DEFLECTIONS

Concrete's modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$
Creep factor $K = 2.00$
Ieffective/Igross... (due to cracking) $K = 1.00$

Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
Values in parentheses are (span/max deflection) ratios

SPAN	<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>				
	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-	2-	3-	4-	5-	6-
CANL	.6	.2	.7 (477)	.2 (1711)	1.0 (373)
1	.4	.3	.8 (993)	.1 (6347)	1.0 (859)
2	.4	.1	.4 (2110)	.1 (6331)	.5 (1582)
3	.4	.2	.5 (1741)	.1 (6331)	.6 (1365)
4	.4	.2	.5 (1750)	.1 (6332)	.6 (1371)
5	.4	.2	.5 (1699)	.1 (6278)	.6 (1337)
CANR	.2	.1	.3 (1089)	.1 (3604)	.3 (836)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION STRUCTURAL CONCRETE SOFTWARE SYSTEM 1733 Woodside Road, Suite 220, Redwood City, California 94061
ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN Version 7.10 AMERICAN (ACI 318-99/UBC-77) ADAPT CORPORATION - Structural Concrete Software System 1733 Woodside Road, Suite 220, Redwood City, California 94061 Phone: (650)306-2400, Fax: (650)364-4678 Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 12, 2020 At Time: 13:7
PROJECT FILE: FL2-C7

PROJECT TITLE:
Government Complex
FL2-C7

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS	350.00 Kg/cm ²
for COLUMNS	350.00 Kg/cm ²
MODULUS OF ELASTICITY for BEAMS/SLABS	287.00 T/cm ²
for COLUMNS	287.00 T/cm ²
CREEP factor for deflections for BEAMS/SLABS	2.00
CONCRETE WEIGHT	NORMAL
SELF WEIGHT	2400.00 Kg/m ³

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top	1.590
At Bottom	1.590

COMPRESSION STRESS limits (multiple of (f'c))

At all locations	.450
------------------------	------

REINFORCEMENT:

YIELD Strength	4.00 T/cm ²
Minimum Cover at TOP	1.50 cm
Minimum Cover at BOTTOM	1.50 cm

POST-TENSIONING:

SYSTEM	BONDED
Ultimate strength of strand	19.00 T/cm ²
Average effective stress in strand (final)	10.80 T/cm ²
Strand area	.990 cm ²
Min CGS of tendon from TOP	4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans ..	5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans ..	5.60 cm
Min average precompression	10.00 Kg/cm ²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL2-C7)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S	T	F				TOP		BOTTOM/MIDDLE				
P	Y	O				FLANGE		FLANGE		REF	MULTIPLIER	
A	P	R	LENGTH	WIDTH	DEPTH	width thick.		width thick.		HEIGHT	left	right
N	E	M	m	cm	cm	cm	cm	cm	cm	cm		
1	2	3	4	5	6	7	8	9	10	11	12	13
1	U	1	7.50	800.00	23.00					.00	.50	.50
2	U	1	8.00	800.00	23.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line

2.2 - SUPPORT WIDTH AND COLUMN DATA

JOINT	SUPPORT	<-----	LOWER COLUMN			>-----	<-----	UPPER COLUMN			>-----
	WIDTH	LENGTH	B (DIA)	D	CBC*	LENGTH	B (DIA)	D	CBC*		
	cm	m	cm	cm		m	cm	cm			
1	2	3	4	5	6	7	8	9	10		
1	.00	4.30	.00	.00	(2)	3.60	.00	.00	(2)		
2	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)		
3	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)		

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3

Fixed at near end, roller with rotational fixity at far end .. = 4





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 3
ACI-99

(FL2-C7)

ADAPT-PT V- 7.10

3 - INPUT APPLIED LOADING

<---CLASS--->			<-----TYPE----->					
D = DEAD LOAD			U = UNIFORM		P = PARTIAL UNIFORM			
L = LIVE LOAD			C = CONCENTRATED		M = APPLIED MOMENT			
			Li= LINE LOAD					
SW= SELF WEIGHT Computed from geometry input and treated as dead loading								
Unit selfweight W = 2400.0 Kg/m^3								
SPAN	CLASS	TYPE	Intensity T/m^2	(From ... (m	To) (M m) (T-m or T ...m)	Total on Trib T/m		
-1-----	-2-----	-3-----	-4-----	-5-----	-6-----	-7-----	-8-----	-9-----
1	L	U	.300	.00	7.50			2.400
1	D	U	.370	.00	7.50			2.960
1	SW	U	.	.00	7.50			4.416
2	L	U	.300	.00	8.00			2.400
2	D	U	.370	.00	8.00			2.960
2	SW	U	.	.00	8.00			4.416

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

			UNIFORM (T/m ²),			(CON. or PART.)			(M O M E N T)		
SPAN	CLASS	TYPE	LINE(T/m)	(T@ m or	m-m)	(T-m @	m)		(T-m @	m)	
-1-----	-2-----	-3-----	-4-----	-5-----	-6-----	-7-----	-8-----				
1	L	U	.300								
1	D	U	.370								
2	L	U	.300								
2	D	U	.370								

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75



4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA cm ²	I cm ⁴	Yb cm	Yt cm
-1-----2-----3-----4-----5-----				
1	18400.00	.8111E+06	11.50	11.50
2	18400.00	.8111E+06	11.50	11.50

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2

5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >	
SPAN	M(l)*	Midspan	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----				
1	.00	26.60	-20.92	34.40
2	-46.52	22.08	-31.90	27.11

Note:

* = Centerline moments

< 5.3 REACTIONS (T) >		< 5.4 COLUMN MOMENTS (Tm) ->	
JOINT		Lower columns	Upper columns
-1-----2-----3-----4-----5-----6-----7-----8-----9-----			
1	20.92	.00	.00
2	66.30	1.87	2.13
3	27.11	12.78	14.56



6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->							
<----- left* ----->		<----- midspan ---->		<----- right* ----->		<--SHEAR FORCE-->	
SPAN	max	min	max	min	max	min	left right
-1-----2-----3-----4-----5-----6-----7-----8-----9-----							
1	.00	.00	8.66	-1.05	-16.44	-2.10	-6.81 11.19
2	-15.14	-2.81	7.18	-.87	-8.90	1.07	-10.38 8.82

Note:

* = Centerline moments

< 6.2 REACTIONS (T) >		< 6.3 COLUMN MOMENTS (Tm) ->	
JOINT		LOWER COLUMN	UPPER COLUMN
-1-----2-----3-----4-----5-----6-----7-----8-----9-----			
	max min	max min	max min



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 5
ACI-99

(FL2-C7)

ADAPT-PT V- 7.10

1	7.18	-.37	.00	.00	.00	.00
2	21.57	10.11	4.62	-4.02	5.27	-4.57
3	9.47	-.65	4.83	-.67	5.50	-.76

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases

7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D DEAD LOAD MOMENTS (Tm)

SPAN	<- left* ->	<- midspan ->	<- right* ->
1	.00	26.60	-34.25
2	-31.50	22.08	-14.71

Note:

* = face-of-support

7.2 R E D U C E D LIVE LOAD MOMENTS (Tm)

SPAN	max	min	max	min	max	min
1	.00	.00	8.65	-1.05	-11.14	-1.96
2	-10.25	-2.57	7.18	-.87	-4.79	.83

Note:

* = face-of-support

8 - SUM OF DEAD AND LIVE MOMENTS (Tm)


Maxima of dead load and live load span moments combined
for serviceability checks (1.00DL + 1.00LL)

SPAN	max	min	max	min	max	min
1	.00	.00	35.26	25.55	-45.39	-36.21
2	-41.75	-34.06	29.26	21.21	-19.50	-13.88

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES



Page 6
ACI-99

(FL2-C7)

ADAPT-PT V- 7.10

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:

For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	T E N D O N		P R O F I L E		
	TYPE	X1/L	X2/L	X3/L	A/L
	1	2	3	4	5
1	1	.100	.500	.100	.000
2	1	.100	.500	.100	.000



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION

SPAN	SELECTED VALUES				CALCULATED VALUES		
	FORCE (T/-)	DISTANCE OF CGS (cm)			P/A (Kg/cm ²)	Wbal (T/-)	Wbal (%DL)
		Left	Center	Right			
1	268.564	-11.50	-17.40	-4.20	14.60	3.648	49
2	267.797	-4.20	-17.40	-11.50	14.55	3.197	43

Approximate weight of strand 282.1 Kg

9.35 - TENDON SELECTION DATA:

TYPE	SEL.	FORCE (T)	TENDON EXTENTS	
			<1>	<2>
-1	-2	-3	-4	-5
B	10	12.12	=====	
C	12	12.14	=====	

9.5 REQUIRED MINIMUM POST-TENSIONING FORCES (T)

SPAN	BASED ON STRESS CONDITIONS			BASED ON MINIMUM P/A		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
-1	-2	-3	-4	-5	-6	-7
1	.00	155.72	221.38	184.00	184.00	184.00



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 7 (FL2-C7) ADAPT-PT V- 7.10
ACI-99

2	200.26	104.62	.00	184.00	184.00	184.00
---	--------	--------	-----	--------	--------	--------

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

L E F T *				R I G H T *				
T O P		B O T T O M		T O P		B O T T O M		
max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C	
-1-----2-----3-----4-----5-----6-----7-----8-----9----								
1	-----	-14.30	-----	-14.30	22.42	-----	-----	-51.58
2	19.85	-----	-----	-48.93	2.20	-5.77	-----	-30.78

Note:

* = face-of-support

C E N T E R				
T O P		B O T T O M		
max-T	max-C	max-T	max-C	
-1-----2-----3-----4-----5-----				
1	-----	-44.27	15.08	-----
2	-----	-40.55	11.44	-----

9.7 POST-TENSIONING B A L A N C E D M O M E N T S , S H E A R S & R E A C T I O N S

SPAN	<-- S P A N M O M E N T S (Tm) -->			<-- SPAN SHEARS (T) -->	
	left*	midspan	right*	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----					
1	.00	-14.32	19.29	-.41	-.41
2	17.49	-10.92	7.87	-1.21	-1.21

Note:

* = face-of-support

<--REACTIONS (T)-->		<-- COLUMN MOMENTS (Tm) -->	
-joint-----2-----		Lower columns-----	Upper columns-----
1	.406	.000	.000
2	.801	-1.399	-1.593
3	-1.207	-4.537	-5.168

10 - FACTORED MOMENTS & REACTIONS

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)



Page 8
ACI-99

(FL2-C7)

ADAPT-PT V- 7.10

10.1 FACTORED DESIGN MOMENTS (Tm)

SPAN	<---- left* ---->		<---- midspan ---->		<---- right* ---->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	.00	.00	53.47	36.97	-64.05	-48.45
2	-60.87	-47.81	47.99	34.31	-19.63	-10.08

Note:

* = face-of-support

10.2 SECONDARY MOMENTS (Tm)

SPAN	<-- left* -->	<- midspan ->	<-- right* -->
-1-----2-----3-----4-----			
1	.00	1.52	2.84
2	.65	4.88	9.10

Note:

* = face-of-support



10.3 FACTORED REACTIONS (T)

JOINT	(T)		10.4 FACTORED COLUMN MOMENTS (Tm)		<-- LOWER column -->		<-- UPPER column -->	
	max	min	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----								
1	41.90	29.06	.00	.00	.00	.00	.00	.00
2	130.29	110.81	9.08	-5.61	10.34	-6.39	10.34	-6.39
3	52.84	35.65	21.56	12.22	24.57	13.92	24.57	13.92

11 - M I L D S T E E L

Support	cut-off length for minimum steel (length/span) ...	.17
Span	cut-off length for minimum steel (length/span) ...	.33
Top	bar extension beyond where required	30.00 cm
Bottom	bar extension beyond where required	30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1	TOTAL WEIGHT OF REBAR =	22.8 Kg	AVERAGE =	.2 Kg/m ²
	TOTAL AREA COVERED =	124.00 m ²		

11.2.1 STEEL AT MID - SPAN

T O P					B O T T O M				
As DIFFERENT REBAR CRITERIA					As DIFFERENT REBAR CRITERIA				
SPAN	(cm ²)	<---ULT---	<---TENS---	<---TENS---	(cm ²)	<---ULT---	<---TENS---	<---TENS---	<---TENS---
-1-----2-----3-----4-----5-----6-----7-----8-----9-----									
1	.0	(	.0	.0	3.1	(	3.1	.0	.0)

2 .0 (.0 .0 .0) .0 (.0 .0 .0)

11.3.1 STEEL AT SUPPORTS

JOINT	T O P					B O T T O M				
	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT	---MIN	---	>		<---ULT	---MIN	---	>
1	2	3	4	5	6	7	8	9		
1	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
2	7.4	(	7.4	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]	AREA [cm ²]
1	2	3	4	5	6	7
1	1	T	4 #	5 x	60	8.0
1	2	B	1 #	6 x	136	2.8
1	3	B	1 #	6 x	98	2.8

Notes:

Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.

Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.

11.5.1 ARRANGEMENT OF TOP BARS

T O P S T E E L					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
1	2	3	4	5	6
1	1	RIGHT	4 #	5 x	60
2	1	LEFT	2 #	5 x	30

11.5.2 ARRANGEMENT OF BOTTOM BARS

B O T T O M S T E E L					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
1	2	3	4	5	6
1	2	CENTER	1 #	6 x	135
1	3	CENTER	1 #	6 x	97



12 - PUNCHING SHEAR CHECK

LEGEND:



CONDITION... 1 = INTERIOR COLUMN
2 = END COLUMN
3 = CORNER COLUMN
4 = EDGE COLUMN (PARALLEL TO SPAN)
5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
PERFORM SHEAR CHECK MANUALLY
6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR

CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)
2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

		FACTORED ACTIONS		<- PUNCHING SHEAR STRESSES IN Kg/cm ² ->						
		shear	moment	due to	due to		allow-	STRESS		
JNT	COND.	T	T-m	shear	moment	TOTAL	able	RATIO	CASE	
-1-	2-	3-	4-	5-	6-	7-	8-	9-	10-	
1	6									
2	1	130.29	19.42	14.88	2.44	17.32	17.96	.96	1	
3	2	52.84	46.13	8.30	6.16	14.46	16.56	.87	1	

PUNCHING SHEAR CHECK NOT CARRIED OUT FOR SUPPORT WITH CONDITIONS 5 OR 6

13 - MAXIMUM SPAN DEFLECTIONS

Concrete's modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$
Creep factor $K = 2.00$
Ineffective/Igross... (due to cracking) $K = 1.00$

Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
Values in parentheses are (span/max deflection) ratios

<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>					
SPAN	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-	2-	3-	4-	5-	6-
1	.6	.3	.8 (886)	.2 (4139)	1.0 (730)
2	.4	.2	.7 (1166)	.1 (5845)	.8 (972)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION STRUCTURAL CONCRETE SOFTWARE SYSTEM 1733 Woodside Road, Suite 220, Redwood City, California 94061
ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN Version 7.10 AMERICAN (ACI 318-99/UBC-77) ADAPT CORPORATION - Structural Concrete Software System 1733 Woodside Road, Suite 220, Redwood City, California 94061 Phone: (650) 306-2400, Fax: (650) 364-4678 Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 12, 2020 At Time: 13:42
PROJECT FILE: FL3-CG

PROJECT TITLE:
Government Complex
FL3-CG

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS	350.00 Kg/cm ²
for COLUMNS	350.00 Kg/cm ²
MODULUS OF ELASTICITY for BEAMS/SLABS	287.00 T/cm ²
for COLUMNS	287.00 T/cm ²
CREEP factor for deflections for BEAMS/SLABS	2.00
CONCRETE WEIGHT	NORMAL
SELF WEIGHT	2400.00 Kg/m ³

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top	1.590
At Bottom	1.590

COMPRESSION STRESS limits (multiple of (f'c))

At all locations	.450
------------------------	------

REINFORCEMENT:

YIELD Strength	4.00 T/cm ²
Minimum Cover at TOP	1.50 cm
Minimum Cover at BOTTOM	1.50 cm

POST-TENSIONING:

SYSTEM	BONDED
Ultimate strength of strand	19.00 T/cm ²
Average effective stress in strand (final)	10.80 T/cm ²
Strand area	.990 cm ²
Min CGS of tendon from TOP	4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans ..	5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans ..	5.60 cm
Min average precompression	10.00 Kg/cm ²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL3-CG)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S P A N N E M	T Y P E	F L A N G E				TOP FLANGE		BOTTOM/MIDDLE FLANGE		REF HEIGHT	MULTIPLIER	
			LENGTH	WIDTH	DEPTH	width thick.		width thick.			left	right
						m	cm	cm	cm			
1	2	3	4	5	6	7	8	9	10	11	12	13
1	U	1	8.40	800.00	23.00					.00	.50	.50
2	U	1	8.40	800.00	23.00					.00	.50	.50
3	U	1	8.40	800.00	23.00					.00	.50	.50
C	U	1	2.80	800.00	23.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line


2.2 - SUPPORT WIDTH AND COLUMN DATA

J O I N T	S U P P O R T		<----- L O W E R C O L U M N ----->				<----- U P P E R C O L U M N ----->			
	W I D T H	L E N G T H	B (DIA)	D	CBC*		L E N G T H	B (DIA)	D	CBC*
		m	cm	cm			m	cm	cm	
1	80.00	4.30	100.00	80.00	(1)		3.60	100.00	80.00	(1)
2	80.00	4.30	100.00	80.00	(1)		3.60	100.00	80.00	(1)
3	80.00	4.30	100.00	80.00	(1)		3.60	100.00	80.00	(1)
4	80.00	4.30	100.00	80.00	(1)		3.60	100.00	80.00	(1)

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2





Fixed at near end, hinged at far end = 3
Fixed at near end, roller with rotational fixity at far end .. = 4

3 - INPUT APPLIED LOADING

<---CLASS--->			<-----TYPE----->				
D = DEAD LOAD			U = UNIFORM		P = PARTIAL UNIFORM		
L = LIVE LOAD			C = CONCENTRATED		M = APPLIED MOMENT		
			Li= LINE LOAD				
SW= SELF WEIGHT Computed from geometry input and treated as dead loading							
Unit selfweight W = 2400.0 Kg/m^3							
SPAN	CLASS	TYPE	Intensity T/m^2	(From ... (m	To) m)	(M or C ...At) (T-m or T ...m)	Total on Trib T/m
-1-----	2-----	3-----	4-----	5-----	6-----	7-----	8-----
1	L	U	.300	.00	8.40		2.400
1	D	U	.370	.00	8.40		2.960
1	SW	U		.00	8.40		4.416
2	L	U	.300	.00	8.40		2.400
2	D	U	.370	.00	8.40		2.960
2	SW	U		.00	8.40		4.416
3	L	U	.300	.00	8.40		2.400
3	D	U	.370	.00	8.40		2.960
3	SW	U		.00	8.40		4.416
CANT	D	U	.370	.00	2.80		2.960
CANT	D	U	.370	.00	2.80		2.960
CANT	SW	U		.00	2.80		4.416

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

			UNIFORM				
			(T/m ²),	(CON. or PART.)	(M O M E N T)		
SPAN	CLASS	TYPE	LINE(T/m)	(T@m or m-m)	(T-m @ m)		
-1-----	2-----	3-----	4-----	5-----	6-----	7-----	8-----
1	L	U	.300				
1	D	U	.370				
2	L	U	.300				
2	D	U	.370				





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 4
ACI-99

(FL3-CG)

ADAPT-PT V- 7.10

3	L	U	.300
3	D	U	.370
CANT	D	U	.370
CANT	D	U	.370

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75

4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA cm ²	I cm ⁴	Yb cm	Yt cm
-1-----2-----3-----4-----5-----				
1	18400.00	.8111E+06	11.50	11.50
2	18400.00	.8111E+06	11.50	11.50
3	18400.00	.8111E+06	11.50	11.50
CANT.	18400.00	.8111E+06	11.50	11.50

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2

5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >		
SPAN	M(l)*	Midspan	M(r)*	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----					
1	-29.97	25.72	-48.70	-28.75	33.21
2	-44.96	21.18	-42.79	-31.24	30.72
3	-43.49	22.04	-42.55	-31.09	30.87
CANT	-40.52	-----	-----	-28.94	-----

Note:

* = Centerline moments

JOINT	< 5.3 REACTIONS (T) >	<- 5.4 COLUMN MOMENTS (Tm) ->
-1-----2-----3-----4-----		Lower columns---Upper columns---
1	28.75	-14.01 -15.96
2	64.45	1.75 1.99
3	61.81	-.33 -.38
4	59.81	.95 1.08



Page 5
ACI-99

(FL3-CG)

ADAPT-PT V- 7.10

6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->

<----- left* ----->		<---- midspan ---->		<---- right* ----->		<--SHEAR FORCE-->		
SPAN	max	min	max	min	max	min	left	right
-1-----2-----3-----4-----5-----6-----7-----8-----9--								
1	-9.77	1.02	8.39	-.87	-15.78	-2.41	-9.36	10.80
2	-14.43	-1.75	6.80	-1.75	-14.43	-1.75	-10.08	10.08
3	-15.78	-2.41	8.39	-.87	-9.77	1.02	-10.80	9.36
CR	.00						.00	

Note:

* = Centerline moments

<- 6.2 REACTIONS (T) -> <----- 6.3 COLUMN MOMENTS (Tm) ----->

		<--- LOWER COLUMN --->		<--- UPPER COLUMN --->		
JOINT	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	9.96	-.60	.63	-5.20	.72	-5.93
2	21.60	9.96	4.57	-3.93	5.20	-4.48
3	21.60	9.96	3.93	-4.57	4.48	-5.20
4	9.96	-.60	5.20	-.63	5.93	-.72

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases


7 - MOMENTS REDUCED TO FACE-OF-SUPPORT

7.1 REDUCED DEAD LOAD MOMENTS (Tm)

SPAN	<- left* ->	<- midspan ->	<- right* ->
-1-----2-----3-----4-----			
1	-19.06	25.72	-36.00
2	-33.05	21.18	-31.09
3	-31.65	22.04	-30.79
CANT	-29.77	-----	-----

Note:

* = face-of-support



7.2 REDUCED LIVE LOAD MOMENTS (Tm)

<----- left* ----->			<----- midspan ---->		<----- right* ----->	
SPAN	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	-6.22	.84	8.39	-.87	-11.66	-2.25
2	-10.59	-1.75	6.80	-1.75	-10.59	-1.75



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 6
ACI-99

(FL3-CG)

ADAPT-PT V- 7.10

3	-11.66	-2.25	8.39	-.87	-6.22	.84
CR	.00					

Note:

* = face-of-support

8 - SUM OF DEAD AND LIVE MOMENTS (Tm)

=====

Maxima of dead load and live load span moments combined

for serviceability checks (1.00DL + 1.00LL)

SPAN	<----- left* ----->		<---- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----			-4-----	-5-----	-6-----7-----	
1	-25.28	-18.22	34.11	24.85	-47.66	-38.25
2	-43.64	-34.79	27.98	19.43	-41.68	-32.83
3	-43.31	-33.90	30.43	21.17	-37.01	-29.95
CR	-29.77					

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:

For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	TENDON		PROFILE			A/L
	TYPE	X1/L	X2/L	X3/L		
	-1-----	-2-----	-3-----	-4-----	-5-----	
1	1	.100	.500	.100	.000	
2	1	.100	.500	.100	.000	
3	1	.100	.500	.100	.000	
CANT	1	.100				



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION

SPAN	SELECTED VALUES				CALCULATED VALUES		
	FORCE (T/-)	DISTANCE OF CGS (cm)			P/A (Kg/cm ²)	Wbal (T/-)	Wbal (%DL)
		Left	Center	Right			
1	260.269	-11.50	-17.40	-4.20	14.15	2.818	38
2	271.554	-4.20	-17.40	-4.20	14.76	4.064	55
3	262.573	-4.20	-17.40	-4.20	14.27	3.930	53
CANT	251.472	-4.20		-11.50	14.00	4.797	46

Approximate weight of strand 495.9 Kg

9.35 - TENDON SELECTION DATA:

TYPE	SEL.	FORCE (T)	TENDON EXTENTS			
			<1>	<2>	<3>	<C>
A	10	12.03				
B	4	12.03				
C	8	11.86				

9.5 REQUIRED MINIMUM POST-TENSIONING FORCES (T)

SPAN	BASED ON STRESS CONDITIONS			BASED ON MINIMUM P/A		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
1	61.24	163.16	249.94	184.00	184.00	184.00
2	205.21	76.23	183.87	184.00	184.00	184.00
3	198.10	102.52	145.10	184.00	184.00	184.00
CANT	95.07			184.00		

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

	LEFT *				RIGHT *			
	TOP		BOTTOM		TOP		BOTTOM	
	max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
1	10.53			-38.18	27.35			-56.24
2	20.07			-49.09	15.85			-45.30
3	18.50			-47.68	12.15			-40.14
CR	8.82			-36.51				

Note:

* = face-of-support



	C E N T E R			
	TOP		BOTTOM	
	max-T	max-C	max-T	max-C
-1-----	2-----	3-----	4-----	5-----
1	-----	-46.95	18.66	-----
2	-----	-33.82	4.31	-7.81
3	-----	-37.38	8.84	-4.29
CR	-----	-----	-----	-----

9.7 POST-TENSIONING B A L A N C E D M O M E N T S , S H E A R S & R E A C T I O N S

SPAN	<-- S P A N M O M E N T S (Tm) -->			<-- SPAN SHEARS (T) -->	
	left*	midspan	right*	SH(l)	SH(r)
-1-----	2-----	3-----	4-----	5-----	6-----
1	8.10	-10.97	18.18	1.16	1.16
2	19.25	-14.54	20.11	-.11	-.11
3	19.97	-14.13	18.57	.10	.10
CANT	13.79	-----	-----	11.14	-----

Note:

* = face-of-support

-joint-----	<--REACTIONS (T)-->		<-- COLUMN MOMENTS (Tm) -->	
	2-----	3-----	Lower columns-----	Upper columns-----
1	-1.162		4.330	4.932
2	1.276		.705	.803
3	-.216		-.078	-.089
4	.103		-.776	-.884

10 - F A C T O R E D M O M E N T S & R E A C T I O N S


Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
-1-----	2-----	3-----	4-----	5-----	6-----	7-----
1	-28.46	-16.46	54.66	38.91	-70.26	-54.26
2	-63.19	-48.15	43.07	28.54	-58.92	-43.88
3	-61.65	-45.65	47.21	31.46	-51.98	-39.98
CR	-41.68		-----			

Note:

* = face-of-support



10.2 SECONDARY MOMENTS (Tm)

SPAN	<-- left* -->	<- midspan ->	<-- right* -->
-1-----2-----3-----4-----			
1	8.80	4.38	-.03
2	1.09	1.85	2.61
3	2.48	2.09	1.70

Note:

* = face-of-support



10.3 FACTORED REACTIONS (T)

JOINT	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	56.03	38.07	-14.21	-24.13	-16.18	-27.49
2	128.23	108.43	10.92	-3.54	12.44	-4.03
3	123.04	103.24	6.15	-8.31	7.00	-9.46
4	100.78	82.82	9.40	-.53	10.70	-.60

10.4 FACTORED COLUMN MOMENTS (Tm)

JOINT	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	56.03	38.07	-14.21	-24.13	-16.18	-27.49
2	128.23	108.43	10.92	-3.54	12.44	-4.03
3	123.04	103.24	6.15	-8.31	7.00	-9.46
4	100.78	82.82	9.40	-.53	10.70	-.60

11 - M I L D S T E E L

Support cut-off length for minimum steel(length/span)17
Span cut-off length for minimum steel(length/span)33
Top bar extension beyond where required 30.00 cm
Bottom bar extension beyond where required 30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1	TOTAL WEIGHT OF REBAR =	24.8	Kg	AVERAGE =	.1	Kg/m ²
	TOTAL AREA COVERED =	224.00	m ²			

11.2.1 STEEL AT MID - SPAN

SPAN	As (cm ²)	DIFFERENT REBAR CRITERIA	As (cm ²)	DIFFERENT REBAR CRITERIA
-1-----2-----3-----4-----5-----6-----7-----8-----9-----				
1	.0	(.0 .0 .0)	.0	(.0 .0 .0)
2	.0	(.0 .0 .0)	.0	(.0 .0 .0)
3	.0	(.0 .0 .0)	.0	(.0 .0 .0)

11.3.1 STEEL AT SUPPORTS

JOINT	As (cm ²)	DIFFERENT REBAR CRITERIA	As (cm ²)	DIFFERENT REBAR CRITERIA
-1-----2-----3-----4-----5-----6-----7-----8-----9-----				
1	.0	(.0 .0 .0)	.0	(.0 .0 .0)
2	.0	(.0 .0 .0)	.0	(.0 .0 .0)
3	.0	(.0 .0 .0)	.0	(.0 .0 .0)

--1--	--2--	--3--	--4--	--5--	--6--	--7--	--8--	--9--
1	.0 (	.0	.0	.0)	.0 (	.0	.0	.0)
2	12.7 (	12.7	.0	.0)	.0 (	.0	.0	.0)
3	.0 (	.0	.0	.0)	.0 (	.0	.0	.0)
4	.0 (	.0	.0	.0)	.0 (	.0	.0	.0)

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]	AREA [cm ²]
--1--	--2--	--3--	--4--	--5--	--6--	--7--
1	1	T	4 #	5 x	144	8.0
1	2	T	3 #	5 x	102	6.0

Notes:

Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.

Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.

11.5.1 ARRANGEMENT OF TOP BARS

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
--1--	--2--	--3--	--4--	--5--	--6--
1	1	RIGHT	4 #	5 x	72
1	2	RIGHT	3 #	5 x	72
2	1	LEFT	4 #	5 x	72
2	2	LEFT	3 #	5 x	30

11.5.2 ARRANGEMENT OF BOTTOM BARS

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
--1--	--2--	--3--	--4--	--5--	--6--

12 - PUNCHING SHEAR CHECK

LEGEND:

- CONDITION... 1 = INTERIOR COLUMN
 2 = END COLUMN
 3 = CORNER COLUMN
 4 = EDGE COLUMN (PARALLEL TO SPAN)
 5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
 PERFORM SHEAR CHECK MANUALLY
 6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 11
ACI-99

(FL3-CG)

ADAPT-PT V- 7.10

CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)
2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

		FACTORED ACTIONS		<- PUNCHING SHEAR STRESSES IN Kg/cm ² ->					
		shear	moment	due to	due to		allow-	STRESS	
JNT	COND.	T	T-m	shear	moment	TOTAL	able	RATIO	CASE
-1-	2-	3-	4-	5-	6-	7-	8-	9-	10-
1	2	56.03	51.62	9.38	7.05	16.43	17.10	.96	1
2	1	128.23	23.36	14.65	2.87	17.52	18.00	.97	1
3	1	123.04	17.77	14.05	2.19	16.24	18.00	.90	1
4	1	100.78	20.10	11.51	2.47	13.98	17.88	.78	1

PUNCHING SHEAR CHECK SATISFACTORY

NO ADDITIONAL REBAR OR CHANGE IN SECTION IS NECESSARY

13 - MAXIMUM SPAN DEFLECTIONS

Concrete's modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$
Creep factor $K = 2.00$
Ineffective/Igross...(due to cracking)..... $K = 1.00$

Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
Values in parentheses are (span/max deflection) ratios

<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>					
SPAN	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-	2-	3-	4-	5-	6-
1	.6	.3	1.0 (815)	.2 (4579)	1.2 (692)
2	.4	.1	.4 (2310)	.1 (6976)	.5 (1735)
3	.4	.2	.5 (1743)	.2 (4582)	.7 (1262)
CANR	.3	.2	.5 (511)	-.1 (2420)	.4 (649)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION STRUCTURAL CONCRETE SOFTWARE SYSTEM 1733 Woodside Road, Suite 220, Redwood City, California 94061
ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN Version 7.10 AMERICAN (ACI 318-99/UBC-77) ADAPT CORPORATION - Structural Concrete Software System 1733 Woodside Road, Suite 220, Redwood City, California 94061 Phone: (650)306-2400, Fax: (650)364-4678 Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 16, 2020 At Time: 15:20
PROJECT FILE: FL5-C10--TOP

PROJECT TITLE:
Government Complex
FL5-C10--TOP

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS	350.00 Kg/cm ²
for COLUMNS	350.00 Kg/cm ²

MODULUS OF ELASTICITY for BEAMS/SLABS

for COLUMNS	287.00 T/cm ²
	287.00 T/cm ²

CREEP factor for deflections for BEAMS/SLABS

CONCRETE WEIGHT	2.00
	NORMAL

SELF WEIGHT

	2400.00 Kg/m ³
--	---------------------------

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top	1.590
At Bottom	1.590

COMPRESSION STRESS limits (multiple of (f'c))

At all locations	.450
------------------------	------

REINFORCEMENT:

YIELD Strength	4.00 T/cm ²
Minimum Cover at TOP	1.50 cm
Minimum Cover at BOTTOM	1.50 cm

POST-TENSIONING:

SYSTEM	BONDED
Ultimate strength of strand	19.00 T/cm ²
Average effective stress in strand (final)	10.80 T/cm ²
Strand area.....	.990 cm ²
Min CGS of tendon from TOP.....	4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans..	5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans..	5.60 cm
Min average precompression	10.00 Kg/cm ²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S P A N N E M	T Y P E	F O R M	L E N G T H m	W I D T H c m	D E P T H c m	T O P F L A N G E		B O T T O M / M I D D L E F L A N G E		R E F H E I G H T c m	M U L T I P L I E R	
						width	thick.	width	thick.		left	right
1	2	3	4	5	6	7	8	9	10	11	12	13
C	U	1	3.00	840.00	23.00					.00	.50	.50
1	U	1	8.00	840.00	23.00					.00	.50	.50
2	N	1	8.00	840.00	23.00					.00	.50	.50
C	N	1	4.45	840.00	35.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line

2.1.2 DETAILED DATA FOR NONUNIFORM SPANS

The following are geometry of nonuniform spans and/or cantilevers.

Left distance is from left support centerline to start of a span segment.

S E G M	F O R M				TOP FLANGE		BOTTOM/MIDDLE FLANGE		REF HEIGHT	MULTIPLIER	
		LEFT DISTANCE	WIDTH	DEPTH	width thick.		width thick.			left	right
G	M	m	cm	cm	cm	cm	cm	cm	cm		
1	2	4	5	6	7	8	9	10	11	12	13
SPAN: 2											
1	1	.00	840.00	23.00					.00	.50	.50
2	1	.50	840.00	23.00					.00	.50	.50
3	1	6.50	840.00	35.00					.00	.50	.50
4	1	7.50	840.00	35.00					.00	.50	.50





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 3
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

CANTILEVER RIGHT

1	1	.00	840.00	35.00		.00	.50	.50
2	1	2.50	840.00	35.00		.00	.50	.50
3	1	2.50	840.00	23.00		.00	.50	.50

2.2 - SUPPORT WIDTH AND COLUMN DATA

JOINT	SUPPORT		<----- LOWER COLUMN ----->				<----- UPPER COLUMN ----->			
	WIDTH	LENGTH	B (DIA)	D	CBC*	LENGTH	B (DIA)	D	CBC*	
	cm	m	cm	cm		m	cm	cm		
--1--	--2--	--3--	--4--	--5--	--6--	--7--	--8--	--9--	--10--	
1	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	
2	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	
3	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3

Fixed at near end, roller with rotational fixity at far end .. = 4

3 - INPUT APPLIED LOADING

<---CLASS--->

D = DEAD LOAD

L = LIVE LOAD

<-----TYPE----->

U = UNIFORM

P = PARTIAL UNIFORM

C = CONCENTRATED

M = APPLIED MOMENT

Li = LINE LOAD

SW= SELF WEIGHT Computed from geometry input and treated as dead loading

Unit selfweight W = 2400.0 Kg/m³

SPAN	CLASS	TYPE	Intensity		(From ... To)	(M or C ... At)	Total on Trib
			T/m ²	(m)		(T-m or T ... m)	
-1--	-2--	-3--	-4--	-5--	-6--	-7--	-8--
CANT	L	U	.300	.00	3.00		2.520
CANT	D	U	.370	.00	3.00		3.108
CANT	SW	U		.00	3.00		4.637
1	L	U	.300	.00	8.00		2.520
1	D	U	.370	.00	8.00		3.108
1	SW	U		.00	8.00		4.637
2	L	U	.300	.00	.50		2.520
2	L	U	.300	.50	6.50		2.520



Page 4
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

2	L	U	.300	6.50	7.50	2.520
2	L	U	.300	7.50	8.00	2.520
2	D	U	.370	.00	.50	3.108
2	D	U	.370	.50	6.50	3.108
2	D	U	.370	6.50	7.50	3.108
2	D	U	.370	7.50	8.00	3.108
2	SW	P		.00	.50	4.637
2	SW	P		.50	6.50	4.637
2	SW	P		6.50	7.50	7.056
2	SW	P		7.50	8.00	7.056
CANT	L	U	.300	.00	2.50	2.520
CANT	L	U	.300	2.50	4.45	2.520
CANT	D	U	.370	.00	2.50	3.108
CANT	D	U	.370	2.50	4.45	3.108
CANT	SW	P		.00	2.50	7.056
CANT	SW	P		2.50	4.45	4.637

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

			UNIFORM						
			(T/m^2),	(CON. or PART.)		(M O M E N T)			
SPAN	CLASS	TYPE	LINE (T/m)	(T@ m or m-m)		(T-m @ m)			
-1	-2	-3	-4	-5	-6	-7	-8		
CANT	L	U	.300						
CANT	D	U	.370						
1	L	U	.300						
1	D	U	.370						
2	L	U	.300						
2	D	U	.370						
CANT	L	U	.300						
CANT	D	U	.370						

KINGDOM OF THAILAND

CHOKCHAI KHATKHAJORN

โชคชัย ขัดขจร

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75



4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA	I	Yb	Yt
	cm^2	cm^4	cm	cm
-1	-2	-3	-4	-5
CANT.	19320.00	.8517E+06	11.50	11.50
1	19320.00	.8517E+06	11.50	11.50
2	---	---	---	---



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 5
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

CANT. --- --- ---

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2

4.2 - Computed Section Properties for Segments of Nonprismatic Spans

Section properties are listed for all segments of each span

A= cross-sectional geometry

Yt= centroidal distance to top fiber

I= gross moment of inertia

Yb= centroidal distance to bottom fiber

SPAN (SEGMENT)	AREA cm ²	I cm ⁴	Yb cm	Yt cm
2	3	4	5	
SPAN 2				
1	19320.00	.8517E+06	11.50	11.50
2	19320.00	.8517E+06	11.50	11.50
3	29400.00	.3001E+07	17.50	17.50
4	29400.00	.3001E+07	17.50	17.50
CANTILEVER RIGHT				
1	29400.00	.3001E+07	17.50	17.50
2	29400.00	.3001E+07	17.50	17.50
3	19320.00	.8517E+06	11.50	11.50

5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >		
SPAN	M(l)*	Midspan	M(r)*	SH(l)	SH(r)
-1	-2	-3	-4	-5	-6
CANT	----	----	-34.85	----	23.23
1	-40.11	21.89	-40.02	-30.99	30.97
2	-34.63	14.59	-62.84	-27.79	37.79
CANT	-84.24	----	----	-40.51	----

Note:

* = Centerline moments

JOINT	< 5.3 REACTIONS (T) >	<- 5.4 COLUMN MOMENTS (Tm) ->
-1	-2	Lower columns---Upper columns----
1	54.22	-2.46 -2.80
2	58.76	2.52 2.87
3	78.31	-10.14 -11.26

6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 6
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->

SPAN	<---- left* ----->		<---- midspan ---->		<---- right* ----->		<--SHEAR FORCE-->	
	max	min	max	min	max	min	left	right
-1-----2-----3-----4-----5-----6-----7-----8-----9-----								
CL	-----		-----		-11.34		-----	7.56
1	-13.04	-1.74	7.11	-1.44	-13.05	-.72	-10.08	10.08
2	-11.35	-1.18	5.36	-1.75	-19.34	-1.99	-9.08	11.08
CR	-24.95		-----		-----		-11.21	-----

Note:

* = Centerline moments

<- 6.2 REACTIONS (T) -> <----- 6.3 COLUMN MOMENTS (Tm) ----->

JOINT	<----- LOWER COLUMN ----->		<----- UPPER COLUMN ----->	
	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----				
1	18.14	7.66	4.22	-5.01
2	20.80	8.11	4.45	-3.66
3	23.07	10.14	7.91	-10.56

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases

7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D DEAD LOAD MOMENTS (Tm)

SPAN	<- left* ->	<- midspan ->	<- right* ->
-1-----2-----3-----4-----			
CANT	-----	-----	-24.20
1	-25.59	21.89	-25.51
2	-21.70	14.59	-45.21
CANT	-65.26	-----	-----


Note:

* = face-of-support

7.2 R E D U C E D LIVE LOAD MOMENTS (Tm)

SPAN	<---- left* ----->		<---- midspan ---->		<---- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
CL	-----		-----		-7.88	
1	-8.32	-1.70	7.11	-1.44	-8.32	-.79
2	-7.13	-1.24	5.36	-1.75	-14.12	-1.96
CR	-19.66		-----		-----	

Note:





* = face-of-support

8 - SUM OF DEAD AND LIVE MOMENTS (Tm)

=====

Maxima of dead load and live load span moments combined
for serviceability checks (1.00DL + 1.00LL)

SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----						
CL	-----		-----		-32.08	
1	-33.91	-27.29	29.00	20.45	-33.83	-26.30
2	-28.83	-22.94	19.95	12.84	-59.33	-47.17
CR	-84.92		-----		-----	

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:

For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	TENDON		PROFILE			A/L
	TYPE	X1/L	X2/L	X3/L		
	1	2	3	4	5	
CANT	1			.000		
1	1	.100	.500	.100	.000	
2	2	.000	.500	.165	.000	
CANT	2	.517				



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 8
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

SPAN	FORCE (T/-)	SELECTED VALUES			CALCULATED VALUES		
		<- DISTANCE OF CGS (cm) ->			P/A (Kg/cm ²)	Wbal (T/-)	Wbal (%DL)
		Left	Center	Right			
-1-	-2-	-3-	-4-	-5-	-6-	-7-	-8-
CANT	195.855	-11.50		-4.20	10.35	3.245	42
1	204.877	-4.20	-17.40	-4.20	10.60	3.380	44
2	207.555	-4.20	-17.40	-4.20	10.74	4.268	52
CANT	290.887	-4.20		-11.50	9.89	4.440	49

Approximate weight of strand 372.4 Kg

9.35 - TENDON SELECTION DATA:

TYPE	SEL.	FORCE (T)	TENDON EXTENTS			
			<C>	<1>	<2>	<C>
-1-	-2-	-3-				
A	17	11.94	=====			
C	9	10.63		=====		

9.5 REQUIRED MINIMUM POST - TENSIONING FORCES (T)

SPAN	<- BASED ON STRESS CONDITIONS ->			<- BASED ON MINIMUM P/A ->		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
-1-	-2-	-3-	-4-	-5-	-6-	-7-
CANT			112.07			193.20
1	113.07	76.45	106.98	193.20	193.20	193.20
2	72.37	.00	50.32	193.20	193.20	294.00
CANT	180.63			294.00		

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

	LEFT *				RIGHT *			
	TOP		BOTTOM		TOP		BOTTOM	
	max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
-1-	-2-	-3-	-4-	-5-	-6-	-7-	-8-	-9-
CL					19.41			-39.85
1	17.25			-38.07	14.77			-36.25
2	12.18			-34.01	5.81	-1.28		-26.13
CR	16.79			-37.13				

Note:

* = face-of-support

CENTER			
TOP		BOTTOM	
max-T	max-C	max-T	max-C





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 9
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

-1-	-2-	-3-	-4-	-5-
CL	-----	-----	-----	-----
1	-----	-35.13	13.93	-----
2	-----	-22.68	1.19	-8.41
CR	-----	-----	-----	-----

9.7 POST-TENSIONING BALANCED MOMENTS, SHEARS & REACTIONS

SPAN	<-- SPAN left* -->	MOMENTS (Tm) -->	<-- SPAN SHEARS (T) -->	
		midspan	right*	
-1-	-2-	-3-	-4-	-5-
CANT	-----	-----	10.13	-----
1	13.42	-10.84	14.94	-----
2	11.72	-11.11	31.94	-----
CANT	38.69	-----	-----	-----

Note:

* = face-of-support

-joint-	<-- REACTIONS (T) -->	<-- COLUMN MOMENTS (Tm) -->	
		Lower columns	Upper columns
1	.191	.559	.637
2	-.722	.581	.662
3	.530	3.043	3.379

10 - FACTORED MOMENTS & REACTIONS

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

SPAN	<----- left* ----->	<----- midspan ----->	<----- right* ----->
	max min	max min	max min
-1-	-2-	-3-	-4-
CL	-----	-----	-47.27
1	-49.06	-37.82	41.63
2	-44.95	-34.94	27.09
CR	-124.79	-----	13.14

Note:

* = face-of-support

10.2 SECONDARY MOMENTS (Tm)

SPAN	<-- left* -->	<-- midspan -->	<-- right* -->
-1-	-2-	-3-	-4-
1	.91	-1.12	-3.14





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 10
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

2 -2.45 -4.30 -6.16

Note:

* = face-of-support

10.3 FACTORED REACTIONS (T)			10.4 FACTORED COLUMN MOMENTS (Tm)			
JOINT			<-- LOWER column -->		<-- UPPER column -->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	106.94	89.12	4.28	-11.41	4.88	-12.99
2	116.90	95.33	11.68	-2.11	13.30	-2.40
3	149.38	127.40	2.29	-29.10	2.54	-32.33

11 - M I L D S T E E L

Support cut-off length for minimum steel(length/span)17
Span cut-off length for minimum steel(length/span)33
Top bar extension beyond where required 30.00 cm
Bottom bar extension beyond where required 30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1 TOTAL WEIGHT OF REBAR = 44.5 Kg AVERAGE = .2 Kg/m²
TOTAL AREA COVERED = 196.98 m²

11.2.1 S T E E L A T M I D - S P A N

T O P					B O T T O M				
SPAN	As (cm ²)	DIFFERENT REBAR CRITERIA			As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	<---TENS---	<---TENS---		<---ULT---	<---TENS---	<---TENS---	
-1-----2-----3-----4-----5-----6-----7-----8-----9-----									
1	.0 (	.0	.0	.0)	.0 (	.0	.0	.0)	
2	.0 (	.0	.0	.0)	.0 (	.0	.0	.0)	

11.3.1 S T E E L A T S U P P O R T S

T O P					B O T T O M				
JOINT	As (cm ²)	DIFFERENT REBAR CRITERIA			As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	<---MIN---	<---MIN---		<---ULT---	<---MIN---	<---MIN---	
-1-----2-----3-----4-----5-----6-----7-----8-----9-----									
1	4.2 (	4.2	.0	.0)	.0 (	.0	.0	.0)	
2	8.4 (	8.4	.0	.0)	.0 (	.0	.0	.0)	
3	.0 (	.0	.0	.0)	.0 (	.0	.0	.0)	

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN ID LOCATION NUM BAR LENGTH [cm] AREA [cm²]



--1--	--2--	--3--	--4--	--5--	--6--	--7--
0	1	T	2 #	5 x	120	4.0
0	2	T	2 #	5 x	60	4.0
1	3	T	5 #	5 x	60	10.0

Notes:

Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.

Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.

11.5.1 ARRANGEMENT OF TOP BARS

TOP STEEL					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
--1--	--2--	--3--	--4--	--5--	--6--
0	1	RIGHT	2 #	5 x	90
0	2	RIGHT	2 #	5 x	60
1	1	LEFT	2 #	5 x	30
1	3	RIGHT	5 #	5 x	30
1	2	LEFT	2 #	5 x	30
2	3	LEFT	3 #	5 x	30

11.5.2 ARRANGEMENT OF BOTTOM BARS

BOTTOM STEEL					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
--1--	--2--	--3--	--4--	--5--	--6--



12 - PUNCHING SHEAR CHECK

LEGEND:

- CONDITION... 1 = INTERIOR COLUMN
 2 = END COLUMN
 3 = CORNER COLUMN
 4 = EDGE COLUMN (PARALLEL TO SPAN)
 5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
 PERFORM SHEAR CHECK MANUALLY
 6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR
- CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)
 2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

FACTORED ACTIONS <- PUNCHING SHEAR STRESSES IN Kg/cm² ->



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 12
ACI-99

(FL5-C10--TOP)

ADAPT-PT V- 7.10

JNT	COND.	shear T	moment T-m	due to shear	due to moment	TOTAL	allow- able	STRESS RATIO	CASE
-1-	2-	3-	4-	5-	6-	7-	8-	9-	10-
1	1	106.94	24.40	12.22	3.06	15.27	16.94	.90	1
2	1	116.90	24.98	13.35	3.13	16.49	16.98	.97	1
3	1	149.38	61.43	9.60	3.87	13.47	17.70	.76	1

PUNCHING SHEAR CHECK SATISFACTORY


NO ADDITIONAL REBAR OR CHANGE IN SECTION IS NECESSARY

13 - MAXIMUM SPAN DEFLECTIONS

Concrete`s modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$
 Creep factor $K = 2.00$
 Ieffective/Igross... (due to cracking) $K = 1.00$

Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
 Values in parentheses are (span/max deflection) ratios

<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>					
SPAN	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-	2-	3-	4-	5-	6-
CANL	.3	.1	.4 (688)	.1 (3460)	.5 (574)
1	.4	.2	.6 (1298)	.1 (6570)	.7 (1084)
2	.2	.0	.1 (6561)	.1 (12579)	.2 (4312)
CANR	.6	.1	.3 (1728)	.2 (2529)	.4 (1027)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION
STRUCTURAL CONCRETE SOFTWARE SYSTEM
1733 Woodside Road, Suite 220, Redwood City, California 94061

ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN
Version 7.10 AMERICAN (ACI 318-99/UBC-77)
ADAPT CORPORATION - Structural Concrete Software System
1733 Woodside Road, Suite 220, Redwood City, California 94061
Phone: (650)306-2400, Fax: (650)364-4678
Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 13, 2020 At Time: 14:17
PROJECT FILE: FL5-CE

PROJECT TITLE:

Data center
FL5-CE

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS 350.00 Kg/cm²
for COLUMNS 350.00 Kg/cm²

MODULUS OF ELASTICITY for BEAMS/SLABS 287.00 T/cm²
for COLUMNS 287.00 T/cm²

CREEP factor for deflections for BEAMS/SLABS 2.00
CONCRETE WEIGHT NORMAL

SELF WEIGHT 2400.00 Kg/m³

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top 1.590
At Bottom 1.590

COMPRESSION STRESS limits (multiple of (f'c))


At all locations450

REINFORCEMENT:

YIELD Strength 4.00 T/cm²
Minimum Cover at TOP 1.50 cm
Minimum Cover at BOTTOM 1.50 cm

POST-TENSIONING:

SYSTEM BONDED
Ultimate strength of strand 19.00 T/cm²
Average effective stress in strand (final) 10.80 T/cm²
Strand area990 cm²
Min CGS of tendon from TOP 4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans.. 5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans.. 5.60 cm
Min average precompression 10.00 Kg/cm²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL5-CB)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S P A N N E M	T Y P E	F L O O R	L E N G T H m	W I D T H cm	D E P T H cm	T O P F L A N G E		B O T T O M / M I D D L E F L A N G E		R E F H E I G H T cm	M U L T I P L I E R	
						width	thick.	width	thick.		left	right
-1-	2-	3-	4-	5-	6-	7-	8-	9-	10-	11-	12-	13-
C	U	1	3.55	800.00	23.00					.00	.50	.50
1	U	1	8.40	800.00	23.00					.00	.50	.50
2	U	1	8.00	800.00	23.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line

2.2 - SUPPORT WIDTH AND COLUMN DATA

J O I N T	S U P P O R T		<----- L O W E R C O L U M N ----->				<----- U P P E R C O L U M N ----->			
	W I D T H cm	L E N G T H m	B (D I A) cm	D cm	C B C *		L E N G T H m	B (D I A) cm	D cm	C B C *
-1-	2-	3-	4-	5-	6-	7-	8-	9-	10-	
1	80.00	4.30	100.00	80.00	(1)	3.60	100.00	80.00	(1)	
2	80.00	4.30	100.00	80.00	(1)	3.60	100.00	80.00	(1)	
3	.00	4.30	.00	.00	(2)	3.65	.00	.00	(2)	

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3

Fixed at near end, roller with rotational fixity at far end .. = 4



3 - INPUT APPLIED LOADING

<---CLASS--->

D = DEAD LOAD

L = LIVE LOAD

<-----TYPE----->

U = UNIFORM

P = PARTIAL UNIFORM

C = CONCENTRATED

M = APPLIED MOMENT

Li= LINE LOAD

SW= SELF WEIGHT Computed from geometry input and treated as dead loading

Unit selfweight W = 2400.0 Kg/m³

SPAN	CLASS	TYPE	Intensity T/m ²	(From ... (m	To) m)	(M or C ...At) (T-m or T ...m)	Total on Trib T/m
-1-----	2-----	3-----	4-----	5-----	6-----	7-----	8-----
CANT	L	U	.300	.00	3.55		2.400
CANT	D	U	.370	.00	3.55		2.960
CANT	SW	U		.00	3.55		4.416
1	L	U	.300	.00	8.40		2.400
1	D	U	.370	.00	8.40		2.960
1	SW	U		.00	8.40		4.416
2	L	U	.300	.00	8.00		2.400
2	D	U	.370	.00	8.00		2.960
2	SW	U		.00	8.00		4.416

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

SPAN	CLASS	TYPE	UNIFORM (T/m ²), LINE(T/m)	(CON. or PART.) (T@m or m-m)	(M O M E N T) (T-m @ m)
-1-----	2-----	3-----	4-----	5-----	6-----
CANT	L	U	.300		
CANT	D	U	.370		
1	L	U	.300		
1	D	U	.370		
2	L	U	.300		
2	D	U	.370		

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75





4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA cm ²	I cm ⁴	Yb cm	Yt cm
-1-----2-----3-----4-----5-----				
CANT.	18400.00	.8111E+06	11.50	11.50
1	18400.00	.8111E+06	11.50	11.50
2	18400.00	.8111E+06	11.50	11.50

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2

5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >	
SPAN	M(l)*	Midspan	M(r)*	SH(l) SH(r)
-1-----2-----3-----4-----5-----6-----				
CANT	----	----	-46.48	----- 26.18
1	-42.92	20.23	-46.73	-30.53 31.43
2	-55.63	31.19	.00	-36.46 22.55

Note:

* = Centerline moments

JOINT	< 5.3 REACTIONS (T) >	<- 5.4 COLUMN MOMENTS (Tm) ->
-1-----2-----3-----4-----5-----6-----7-----8-----9-----		Lower columns-----Upper columns-----
1	56.71	1.66 1.89
2	67.89	-4.16 -4.74
3	22.55	.00 .00

6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->

<----- left* ----->		<----- midspan ----->		<----- right* ----->		<--SHEAR FORCE-->		
SPAN	max	min	max	min	max	min	left	right
-1-----2-----3-----4-----5-----6-----7-----8-----9-----								
CL	-----	-----	-----	-----	-15.12	-----	-----	8.52
1	-13.97	-2.22	7.09	-2.15	-15.21	-2.09	-9.93	10.23
2	-18.10	-2.16	10.15	-1.27	.00	.00	-11.86	7.34



Note:

* = Centerline moments

<- 6.2 REACTIONS (T) ->			<----- 6.3 COLUMN MOMENTS (Tm) ----->			
			<--- LOWER COLUMN --->		<--- UPPER COLUMN --->	
JOINT	max	min	max	min	max	min
-1-----2-----3-----			4-----5-----		6-----7-----	
1	19.21	8.54	5.69	-5.15	6.48	-5.86
2	22.93	9.83	4.22	-5.58	4.81	-6.35
3	7.76	-.42	.00	.00	.00	.00

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases

7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D DEAD LOAD MOMENTS (Tm)

SPAN	<- left* ->	<- midspan ->	<- right* ->
-1-----2-----3-----4-----			
CANT	-----	-----	-36.59
1	-31.30	20.23	-34.75
2	-41.64	31.19	.00

Note:

* = face-of-support



7.2 R E D U C E D LIVE LOAD MOMENTS (Tm)

SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
CL	-----	-----	-----	-----	-11.91	-----
1	-10.18	-2.21	7.09	-2.15	-11.31	-2.09
2	-13.55	-2.06	10.15	-1.27	.00	.00

Note:

* = face-of-support

8 - SUM OF DEAD AND LIVE MOMENTS (Tm)

Maxima of dead load and live load span moments combined
for serviceability checks (1.00DL + 1.00LL)

SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 6
ACI-99

(FL5-CE)

ADAPT-PT V- 7.10

CL	-----	-----	-----	-----	-48.50	
1	-41.48	-33.51	27.32	18.08	-46.06	-36.84
2	-55.19	-43.69	41.34	29.92	.00	.00

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:

For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	T E N D O N		P R O F I L E		
	TYPE	X1/L	X2/L	X3/L	A/L
	1	2	3	4	5
CANT	1			.000	
1	1	.100	.500	.100	.000
2	1	.100	.500	.100	.000



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION

SPAN	FORCE (T/-)	SELECTED VALUES			CALCULATED VALUES		
		DISTANCE OF CGS (cm)			P/A (Kg/cm ²)	Wbal (T/-)	Wbal (%DL)
		Left	Center	Right			
1	2	3	4	5	6	7	8
CANT	318.848	-11.50		-4.20	17.60	3.751	51
1	327.937	-4.20	-10.40	-4.20	17.82	2.305	31
2	333.627	-4.20	-17.40	-11.50	18.13	3.983	54

Approximate weight of strand 439.7 Kg

9.35 - TENDON SELECTION DATA:

Page 7
ACI-99

(FL5-CE)

ADAPT-PT V- 7.10

TYPE	SEL.	FORCE (T)	TENDON EXTENTS									
			<C>	<1>	<2>							
-1	2	3										
B	27	12.20	<=====									

9.5 REQUIRED MINIMUM POST - TENSIONING FORCES (T)

SPAN	<- BASED ON STRESS CONDITIONS ->			<- BASED ON MINIMUM P/A ->		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
-1	2	3	4	5	6	7
CANT			286.92			184.00
1	258.63	112.68	311.33	184.00	184.00	184.00
2	318.51	212.85	.00	184.00	184.00	184.00

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

	LEFT *				RIGHT *			
	TOP		BOTTOM		TOP		BOTTOM	
	max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
-1	2	3	4	5	6	7	8	9
CL					24.95			-59.97
1	22.33			-57.62	26.94			-63.45
2	27.06			-63.60		-17.88		-17.88

Note:

* = face-of-support

	CENTER			
	TOP		BOTTOM	
	max-T	max-C	max-T	max-C
-1	2	3	4	5
CL				
1		-48.23	12.58	-.52
2		-49.63	13.37	-2.82

9.7 POST-TENSIONING BALANCED MOMENTS, SHEARS & REACTIONS

SPAN	<- SPAN MOMENTS (Tm) ->			<- SPAN SHEARS (T) ->	
	left*	midspan	right*	SH(l)	SH(r)
-1	2	3	4	5	6
CANT			18.55		11.44
1	13.29	-5.87	14.18	-.07	-.07
2	23.22	-19.12	.00	.14	.14

Note:

* = face-of-support





<-- REACTIONS (T) -->		<-- COLUMN MOMENTS (Tm) -->	
-joint	2	Lower columns	Upper columns
1	.066	-4.276	-4.870
2	-.207	4.825	5.496
3	.140	.000	.000

10 - FACTORED MOMENTS & REACTIONS

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

SPAN	<---- left* ---->		<---- midspan ---->		<---- right* ---->	
	max	min	max	min	max	min
-1	-2	-3	-4	-5	-6	-7
CL					-71.47	
1	-70.27	-56.72	31.20	15.49	-77.07	-61.40
2	-80.26	-60.72	61.48	42.07	.00	.00

Note:

* = face-of-support

10.2 SECONDARY MOMENTS (Tm)

SPAN	<-- left* -->	<-- midspan -->	<-- right* -->
-1	-2	-3	-4
1	-9.15	-9.17	-9.19
2	1.07	.56	.00

Note:

* = face-of-support



10.3 FACTORED REACTIONS (T)

JOINT			10.4 FACTORED COLUMN MOMENTS (Tm)			
	max	min	<-- LOWER column -->	<-- UPPER column -->	max	min
-1	-2	-3	-4	-5	-6	-7
1	112.12	93.98	7.72	-10.70	8.80	-12.19
2	133.82	111.56	6.18	-10.48	7.04	-11.94
3	44.90	30.99	.00	.00	.00	.00

11 - MILD STEEL

Support cut-off length for minimum steel (length/span)17

Span cut-off length for minimum steel (length/span)33
Top bar extension beyond where required 30.00 cm
Bottom bar extension beyond where required 30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1 TOTAL WEIGHT OF REBAR = 40.0 Kg AVERAGE = .3 Kg/m²
TOTAL AREA COVERED = 159.60 m²

11.2.1 STEEL AT MID - SPAN
TOP

SPAN	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	---TENS---	---	---		<---ULT---	---TENS---	---	---
1	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
2	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.3.1 STEEL AT SUPPORTS
TOP

JOINT	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	---MIN---	---	---		<---ULT---	---MIN---	---	---
1	1.8	(	1.8	.0	.0)	.0	(	.0	.0	.0)
2	9.1	(	9.1	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]	AREA [cm ²]
0	1	T	4 #	5 x	60	8.0
1	2	T	5 #	5 x	100	10.0

Notes:

Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.

Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.

11.5.1 ARRANGEMENT OF TOP BARS

SPAN	ID	LOCATION	TOP STEEL		
			NUM	BAR	LENGTH [cm]
0	1	RIGHT	4 #	5 x	60
1	2	RIGHT	5 #	5 x	100





2	2 LEFT	5 # 5 x 70
---	--------	------------



11.5.2 ARRANGEMENT OF BOTTOM BARS

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
-1-	-2-	-3-	-4-	-5-	-6-

12 - PUNCHING SHEAR CHECK

LEGEND:

CONDITION... 1 = INTERIOR COLUMN

2 = END COLUMN

3 = CORNER COLUMN

4 = EDGE COLUMN (PARALLEL TO SPAN)

5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
PERFORM SHEAR CHECK MANUALLY

6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR

CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)

2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

JNT	COND.	FACTORED ACTIONS		<- PUNCHING SHEAR STRESSES IN Kg/cm ² ->				allow- able	STRESS RATIO	CASE
		shear T	moment T-m	due to shear	due to moment	TOTAL				
-1-	-2-	-3-	-4-	-5-	-6-	-7-	-8-	-9-	-10-	
1	1	112.12	22.88	12.81	2.82	15.62	18.78	.83	1	
2	1	133.82	22.42	15.29	2.76	18.04	18.86	.96	1	
3	6									

PUNCHING SHEAR CHECK NOT CARRIED OUT FOR SUPPORT WITH CONDITIONS 5 OR 6

13 - MAXIMUM SPAN DEFLECTIONS

Concrete's modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$ Creep factor $K = 2.00$ Ineffective/ I_{gross} ... (due to cracking)..... $K = 1.00$ Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
Values in parentheses are (span/max deflection) ratios

<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>					
SPAN	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-	-2-	-3-	-4-	-5-	-6-
CANL	.7	.2	.7 (521)	.2 (1582)	.9 (392)



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารที่ศตวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 11
ACI-99

(FL5-CE)

ADAPT-PT V- 7.10

1	.4	.3	.9 (961)	.1 (7346)	1.0 (850)
2	.8	.3	1.0 (837)	.2 (3272)	1.2 (666)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION STRUCTURAL CONCRETE SOFTWARE SYSTEM 1733 Woodside Road, Suite 220, Redwood City, California 94061
ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN Version 7.10 AMERICAN (ACI 318-99/UBC-77) ADAPT CORPORATION - Structural Concrete Software System 1733 Woodside Road, Suite 220, Redwood City, California 94061 Phone: (650)306-2400, Fax: (650)364-4678 Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 12, 2020 At Time: 16:53
PROJECT FILE: FL4-C7

PROJECT TITLE:
Government Complex
FL4-C7

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS	350.00 Kg/cm ²
for COLUMNS	350.00 Kg/cm ²
MODULUS OF ELASTICITY for BEAMS/SLABS	287.00 T/cm ²
for COLUMNS	287.00 T/cm ²
CREEP factor for deflections for BEAMS/SLABS	2.00
CONCRETE WEIGHT	NORMAL
SELF WEIGHT	2400.00 Kg/m ³

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top	1.590
At Bottom	1.590

COMPRESSION STRESS limits (multiple of (f'c))


At all locations	.450
------------------------	------

REINFORCEMENT:

YIELD Strength	4.00 T/cm ²
Minimum Cover at TOP	1.50 cm
Minimum Cover at BOTTOM	1.50 cm

POST-TENSIONING:

SYSTEM	BONDED
Ultimate strength of strand	19.00 T/cm ²
Average effective stress in strand (final)	10.80 T/cm ²
Strand area.....	.990 cm ²
Min CGS of tendon from TOP.....	4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans..	5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans..	5.60 cm
Min average precompression	10.00 Kg/cm ²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL4-C7)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S P A N N E M	T Y P E	F O R M	L E N G T H m	W I D T H cm	D E P T H cm	T O P F L A N G E		B O T T O M / M I D D L E F L A N G E		R E F H E I G H T cm	M U L T I P L I E R	
						width	thick.	width	thick.		left	right
1	2	3	4	5	6	7	8	9	10	11	12	13
1	U	1	7.50	800.00	30.00					.00	.50	.50
2	U	1	8.00	800.00	30.00					.00	.50	.50
3	U	1	4.00	800.00	30.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line

2.2 - SUPPORT WIDTH AND COLUMN DATA

J O I N T	S U P P O R T		<----- L O W E R C O L U M N ----->				<----- U P P E R C O L U M N ----->			
	W I D T H cm	L E N G T H m	B (D I A) cm	D cm	C B C *		L E N G T H m	B (D I A) cm	D cm	C B C *
1	2	3	4	5	6	7	8	9	10	11
1	.00	4.30	.00	.00	(2)	3.60	.00	.00	(2)	
2	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	
3	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	
4	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 3
ACI-99

(FL4-C7)

ADAPT-PT V- 7.10

Fixed at near end, roller with rotational fixity at far end .. = 4

3 - INPUT APPLIED LOADING

<---CLASS--->			<-----TYPE----->					
D = DEAD LOAD			U = UNIFORM			P = PARTIAL UNIFORM		
L = LIVE LOAD			C = CONCENTRATED			M = APPLIED MOMENT		
			Li= LINE LOAD					
SW= SELF WEIGHT Computed from geometry input and treated as dead loading								
Unit selfweight W = 2400.0 Kg/m^3								
SPAN	CLASS	TYPE	Intensity T/m^2	(From ... (m	To) m)	(M or C ...At) (T-m or T ...m)	Total on Trib T/m	
-1-----	2-----	3-----	4-----	5-----	6-----	7-----	8-----	9-----
1	L	U	1.000	.00	7.50			8.000
1	D	U	.370	.00	7.50			2.960
1	SW	U		.00	7.50			5.760
2	L	U	1.000	.00	8.00			8.000
2	D	U	.370	.00	8.00			2.960
2	SW	U		.00	8.00			5.760
3	L	U	1.000	.00	4.00			8.000
3	D	U	.370	.00	4.00			2.960
3	SW	U		.00	4.00			5.760

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

			UNIFORM					
			(T/m ²),	(CON. or PART.)	(M O M E N T)			
SPAN	CLASS	TYPE	LINE(T/m)	(T@m or m-m)	(T-m @ m)			
-1-----	2-----	3-----	4-----	5-----	6-----	7-----	8-----	9-----
1	L	U	1.000					
1	D	U	.370					
2	L	U	1.000					
2	D	U	.370					
3	L	U	1.000					
3	D	U	.370					

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75



4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA cm ²	I cm ⁴	Yb cm	Yt cm
-1-----2-----3-----4-----5-----				
1	24000.00	.1800E+07	15.00	15.00
2	24000.00	.1800E+07	15.00	15.00
3	24000.00	.1800E+07	15.00	15.00

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2



5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >		
SPAN	M(l)*	Midspan	M(r)*	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----					
1	.00	31.86	-58.91	-24.84	40.56
2	-52.54	24.10	-38.78	-36.60	33.16
3	-25.36	3.36	-2.80	-23.08	11.80

Note:

* = Centerline moments

JOINT	< 5.3 REACTIONS (T) >	< 5.4 COLUMN MOMENTS (Tm) ->
-1-----2-----3-----4-----5-----6-----7-----8-----9-----		
1	24.84	.00
2	77.16	3.00
3	56.24	6.32
4	11.80	1.32

6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->									
<---- left* ----->		<---- midspan ---->		<---- right* ----->		<--SHEAR FORCE-->			
SPAN	max	min	max	min	max	min	left	right	
-1-----2-----3-----4-----5-----6-----7-----8-----9-----									



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 5
ACI-99

(FL4-C7)

ADAPT-PT V- 7.10

1	.00	.00	29.23	-3.61	-54.05	-7.01	-22.79	37.21
2	-48.20	-9.48	22.11	-3.55	-35.58	2.39	-33.58	30.42
3	-23.27	-4.39	6.92	-4.61	-5.78	3.85	-21.18	12.35

Note:

* = Centerline moments

<- 6.2 REACTIONS (T) ->			<- 6.3 COLUMN MOMENTS (Tm) ->			
			<--- LOWER COLUMN --->		<--- UPPER COLUMN --->	
JOINT	max	min	max	min	max	min
-1-----2-----3-----						
1	24.08	-1.28	.00	.00	.00	.00
2	71.27	32.40	14.98	-12.22	16.81	-13.72
3	54.86	13.56	10.06	-4.26	11.29	-4.78
4	16.46	-5.64	3.63	-2.42	4.07	-2.72

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases

7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D DEAD LOAD MOMENTS (Tm)			
SPAN	<- left* ->	<- midspan ->	<- right* ->
-1-----2-----3-----4-----			
1	.00	31.86	-39.73
2	-35.33	24.10	-23.29
3	-14.91	3.36	2.01

Note:

* = face-of-support



7.2 R E D U C E D LIVE LOAD MOMENTS (Tm)						
SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	.00	.00	29.23	-3.61	-36.45	-6.54
2	-32.41	-8.74	22.11	-3.55	-21.37	1.64
3	-13.68	.69	6.92	-4.61	-.35	1.84

Note:

* = face-of-support

8 - SUM OF DEAD AND LIVE MOMENTS (Tm)

Maxima of dead load and live load span moments combined

-----
for serviceability checks (1.00DL + 1.00LL)

SPAN	<----- left* ----->		<---- midspan ---->		<----- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----						
1	.00	.00	61.09	28.25	-76.18	-46.27
2	-67.74	-44.07	46.21	20.55	-44.66	-21.65
3	-28.59	-14.22	10.27	-1.25	1.66	3.85

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES
=====

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:

For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	TENDON		PROFILE			A/L
	TYPE	X1/L	X2/L	X3/L		
	-1-----2-----3-----4-----5-----					
1	1	.100	.500	.100	.000	
2	1	.100	.500	.100	.000	
3	1	.100	.500	.100	.000	

9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE
=====

Tendon editing mode selected: TENDON SELECTION

SPAN	SELECTED VALUES				CALCULATED VALUES		
	FORCE (T/-)	DISTANCE OF CGS (cm) ->			P/A (Kg/cm^2)	Wbal (T/-)	Wbal (%DL)
	-1-----2-----3-----4-----5-----6-----7-----8-----						
1	329.148	-15.00	-24.40	-4.20	13.71	6.928	79
2	345.660	-4.20	-24.40	-4.20	14.40	8.728	100
3	319.932	-4.20	-16.40	-15.00	13.33	10.878	125



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 7
ACI-99

(FL4-C7)

ADAPT-PT V- 7.10

Approximate weight of strand 462.1 Kg

9.35 - TENDON SELECTION DATA:

TYPE	SEL.	FORCE (T)	TENDON EXTENTS		
			<1>	<2>	<3>
--1--	2	3	4	5	6
C	29	11.55	=====		

9.5 REQUIRED MINIMUM POST-TENSIONING FORCES (T)

SPAN	<- BASED ON STRESS CONDITIONS ->			<- BASED ON MINIMUM P/A ->		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
--1--	2	3	4	5	6	7
1	.00	193.13	244.15	240.00	240.00	240.00
2	197.30	78.59	61.30	240.00	240.00	240.00
3	.00	.00	.00	240.00	240.00	240.00

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

	LEFT *				RIGHT *			
	TOP		BOTTOM		TOP		BOTTOM	
	max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
--1--	2	3	4	5	6	7	8	9
1	-----	-13.47	-----	-13.47	16.92	-8.00	-----	-45.15
2	9.86	-9.87	-----	-38.55	-----	-22.64	-----	-24.35
3	-----	-15.35	-----	-23.82	-----	-17.02	-----	-11.32

Note:

* = face-of-support

	CENTER			
	TOP		BOTTOM	
	max-T	max-C	max-T	max-C
--1--	2	3	4	5
1	-----	-42.28	14.85	-12.52
2	-----	-28.78	-----	-21.41
3	-----	-15.52	-----	-20.75



9.7 POST-TENSIONING BALANCED MOMENTS, SHEARS & REACTIONS

SPAN	<- SPAN MOMENTS (Tm) ->			<- SPAN SHEARS (T) ->	
	left*	midspan	right*	SH(l)	SH(r)
--1--	2	3	4	5	6
1	.00	-26.81	38.93	-1.10	-1.10
2	38.70	-28.96	32.12	.94	.94



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 8
ACI-99

(FL4-C7)

ADAPT-PT V- 7.10

3 16.32 -7.65 .66 -3.44 -3.44

Note:

* = face-of-support

<-- REACTIONS (T) --> <-- COLUMN MOMENTS (Tm) -->
-joint-----2-----Lower columns-----Upper columns-----
1 1.102 .000 .000
2 -2.041 -.457 -.513
3 4.381 -4.634 -5.201
4 -3.442 -1.749 -1.963

10 - FACTORED MOMENTS & REACTIONS

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

<----- left* -----> <----- midspan -----> <----- right* ----->
SPAN max min max min max min
-1-----2-----3-----4-----5-----6-----7-----
1 .00 .00 98.42 42.60 -109.87 -59.03
2 -97.73 -57.50 74.86 31.24 -68.69 -29.56
3 -52.47 -28.04 13.29 -6.30 4.20 7.94

Note:

* = face-of-support

10.2 SECONDARY MOMENTS (Tm)

SPAN <-- left* --> <-- midspan --> <-- right* -->
-1-----2-----3-----4-----
1 .00 4.13 7.71
2 6.82 3.54 .25
3 -8.34 -3.17 1.99

Note:

* = face-of-support



10.3 FACTORED REACTIONS

(T) <-- LOWER column --> <-- UPPER column -->
JOINT max min max min max min
-1-----2-----3-----4-----5-----6-----7-----
1 76.81 33.70 .00 .00 .00 .00
2 227.14 161.06 29.21 -17.03 32.78 -19.12
3 176.38 106.17 21.32 -3.02 23.93 -3.39



4	41.06	3.49	6.27	-4.02	7.04	-4.51
---	-------	------	------	-------	------	-------

11 - M I L D S T E E L

Support cut-off length for minimum steel (length/span)17
Span cut-off length for minimum steel (length/span)33
Top bar extension beyond where required 30.00 cm
Bottom bar extension beyond where required 30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1 TOTAL WEIGHT OF REBAR = 13.1 Kg AVERAGE = .1 Kg/m²
TOTAL AREA COVERED = 156.00 m²

11.2.1 S T E E L A T M I D - S P A N

SPAN	As (cm ²)	T O P DIFFERENT REBAR CRITERIA				As (cm ²)	B O T T O M DIFFERENT REBAR CRITERIA			
		<---ULT---	---TENS---	---	---		<---ULT---	---TENS---	---	---
1	.0	(	.0	.0	.0)	2.6	(	2.6	.0	.0)
2	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.3.1 S T E E L A T S U P P O R T S

JOINT	As (cm ²)	T O P DIFFERENT REBAR CRITERIA				As (cm ²)	B O T T O M DIFFERENT REBAR CRITERIA			
		<---ULT---	---MIN---	---	---		<---ULT---	---MIN---	---	---
1	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
2	3.9	(	3.9	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
4	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]	AREA [cm ²]
1	1	T	4 #	5 x	60	8.0
1	2	B	1 #	6 x	136	2.8

Notes:

Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.

Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.



11.5.1 ARRANGEMENT OF TOP BARS

SPAN	TOP		STEEL		LENGTH [cm]
	ID	LOCATION	NUM	BAR	
1	1	RIGHT	4 #	5 x	60

11.5.2 ARRANGEMENT OF BOTTOM BARS

SPAN	BOTTOM		STEEL		LENGTH [cm]
	ID	LOCATION	NUM	BAR	
1	2	CENTER	1 #	6 x	135



12 - PUNCHING SHEAR CHECK

LEGEND:

- CONDITION... 1 = INTERIOR COLUMN
 2 = END COLUMN
 3 = CORNER COLUMN
 4 = EDGE COLUMN (PARALLEL TO SPAN)
 5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
 PERFORM SHEAR CHECK MANUALLY
 6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR

- CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)
 2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

JNT	COND.	FACTORED ACTIONS		<- PUNCHING SHEAR STRESSES IN Kg/cm ² ->					
		shear T	moment T-m	due to shear	due to moment	TOTAL	allow- able	STRESS RATIO	CASE
1	6								
2	1	227.14	61.99	18.05	5.05	23.10	18.63	1.24	1
3	1	176.38	45.25	14.01	3.69	17.70	18.63	.95	1
4	2	41.06	13.31	4.57	.37	4.94	17.13	.29	1

PUNCHING SHEAR STRESS IN ONE OR MORE LOCATIONS EXCEEDS THE PERMISSIBLE VALUE. PROVIDE SHEAR REINFORCEMENT, OR ENLARGE THE SECTION RESISTING THE PUNCHING SHEAR

PUNCHING SHEAR CHECK NOT CARRIED OUT FOR SUPPORT WITH CONDITIONS 5 OR 6



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 11
ACI-99

(FL4-C7)


ADAPT-PT V- 7.10

13 - MAXIMUM SPAN DEFLECTIONS

Concrete's modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$
Creep factor $K = 2.00$
Effective/ I_{gross} ... (due to cracking) $K = 1.00$

Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
Values in parentheses are (span/max deflection) ratios

<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>					
SPAN	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-----2-----3-----4-----5-----6-----					
1	.3	.1	.2 (3172)	.3 (2706)	.5 (1460)
2	.2	.0	.0 (*****)	.2 (4557)	.2 (4745)
3	.0	.0	-.1 (7043)	.0 (60746)	-.1 (6311)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION
STRUCTURAL CONCRETE SOFTWARE SYSTEM
1733 Woodside Road, Suite 220, Redwood City, California 94061

ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN
Version 7.10 AMERICAN (ACI 318-99/UBC-77)
ADAPT CORPORATION - Structural Concrete Software System
1733 Woodside Road, Suite 220, Redwood City, California 94061
Phone: (650)306-2400, Fax: (650)364-4678
Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 12, 2020 At Time: 21:51
PROJECT FILE: FL4-C14

PROJECT TITLE:
Government Complex
FL4-C14

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS 350.00 Kg/cm²
for COLUMNS 350.00 Kg/cm²

MODULUS OF ELASTICITY for BEAMS/SLABS 287.00 T/cm²
for COLUMNS 287.00 T/cm²

CREEP factor for deflections for BEAMS/SLABS 2.00
CONCRETE WEIGHT NORMAL

SELF WEIGHT 2400.00 Kg/m³

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top 1.590
At Bottom 1.590

COMPRESSION STRESS limits (multiple of (f'c))

At all locations450

REINFORCEMENT:

YIELD Strength 4.00 T/cm²
Minimum Cover at TOP 1.50 cm
Minimum Cover at BOTTOM 1.50 cm

POST-TENSIONING:

SYSTEM BONDED
Ultimate strength of strand 19.00 T/cm²
Average effective stress in strand (final) 10.80 T/cm²
Strand area990 cm²
Min CGS of tendon from TOP 4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans.. 5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans.. 5.60 cm
Min average precompression 10.00 Kg/cm²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL4-C14)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S P A N N E M	T Y P E	F	LENGTH	WIDTH	DEPTH	TOP FLANGE		BOTTOM/MIDDLE FLANGE		REF HEIGHT	MULTIPLIER	
						width	thick.	width	thick.		left	right
1	2	3	4	5	6	7	8	9	10	11	12	13
1	U	1	7.50	800.00	30.00					.00	.50	.50
2	N	1	8.00	800.00	30.00					.00	.50	.50
C	N	1	3.80	800.00	45.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line

2.1.2 DETAILED DATA FOR NONUNIFORM SPANS

The following are geometry of nonuniform spans and/or cantilevers.
Left distance is from left support centerline to start of a span segment.

F					TOP		BOTTOM/MIDDLE			
S	O	LEFT			FLANGE		FLANGE		REF	MULTIPLIER
E	R	DISTANCE	WIDTH	DEPTH	width thick.		width thick.		HEIGHT	left right
G	M	m	cm	cm	cm	cm	cm	cm	cm	
1-2		4	5	6	7	8	9	10	11	12 13
SPAN: 2										
1	1	.00	800.00	30.00					.00	.50 .50
2	1	.50	800.00	30.00					.00	.50 .50
3	1	6.50	800.00	45.00					.00	.50 .50
4	1	7.50	800.00	45.00					.00	.50 .50
CANTILEVER RIGHT										





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 3
ACI-99

(FL4-C14)

ADAPT-PT V- 7.10

1	1	.00	800.00	45.00	.00	.50	.50
2	1	2.50	800.00	45.00	.00	.50	.50
3	1	2.50	800.00	30.00	.00	.50	.50

2.2 - SUPPORT WIDTH AND COLUMN DATA

JOINT	SUPPORT		<----- LOWER COLUMN ----->				<----- UPPER COLUMN ----->			
	WIDTH	LENGTH	B (DIA)	D	CBC*	LENGTH	B (DIA)	D	CBC*	
	cm	m	cm	cm		m	cm	cm		
-1-	-2-	-3-	-4-	-5-	-6-	-7-	-8-	-9-	-10-	
1	.00	4.30	.00	.00	(2)	3.60	.00	.00	(2)	
2	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	
3	100.00	4.30	80.00	100.00	(1)	3.60	80.00	100.00	(1)	

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3

Fixed at near end, roller with rotational fixity at far end .. = 4

3 - INPUT APPLIED LOADING

<---CLASS--->

D = DEAD LOAD

L = LIVE LOAD

<-----TYPE----->

U = UNIFORM

P = PARTIAL UNIFORM

C = CONCENTRATED

M = APPLIED MOMENT

Li = LINE LOAD

SW= SELF WEIGHT Computed from geometry input and treated as dead loading

Unit selfweight W = 2400.0 Kg/m³

SPAN	CLASS	TYPE	Intensity T/m^2	(From ... (m)	To) (m)	(M or C ...At) (T-m or T ...m)	Total on Trib T/m	
-1-	-2-	-3-	-4-	-5-	-6-	-7-	-8-	-9-
1	L	U	1.000	.00	7.50			8.000
1	D	U	.370	.00	7.50			2.960
1	SW	U		.00	7.50			5.760
2	L	U	1.000	.00	.50			8.000
2	L	U	1.000	.50	6.50			8.000
2	L	U	1.000	6.50	7.50			8.000
2	L	U	1.000	7.50	8.00			8.000
2	D	U	.370	.00	.50			2.960
2	D	U	.370	.50	6.50			2.960







รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 4
ACI-99

(FL4-C14)

ADAPT-PT V- 7.10

2	D	U	.370	6.50	7.50	2.960
2	D	U	.370	7.50	8.00	2.960
2	SW	P		.00	.50	5.760
2	SW	P		.50	6.50	5.760
2	SW	P		6.50	7.50	8.640
2	SW	P		7.50	8.00	8.640
CANT	L	U	1.000	.00	2.50	8.000
CANT	L	U	1.000	2.50	3.80	8.000
CANT	D	U	.370	.00	2.50	2.960
CANT	D	U	.370	2.50	3.80	2.960
CANT	SW	P		.00	2.50	8.640
CANT	SW	P		2.50	3.80	5.760

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

UNIFORM (T/m^2), (CON. or PART.) (M O M E N T)							
SPAN	CLASS	TYPE	LINE(T/m)	(T@m or m-m)	(T-m @ m)		
-1-----	-2-----	-3-----	-4-----	-5-----	-6-----	-7-----	-8-----
1	L	U	1.000				
1	D	U	.370				
2	L	U	1.000				
2	D	U	.370				
CANT	L	U	1.000				
CANT	D	U	.370				

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75

4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA cm^2	I cm^4	Yb cm	Yt cm
-1-----	-2-----	-3-----	-4-----	-5-----
1	24000.00	.1800E+07	15.00	15.00
2	---	---	---	---
CANT.	---	---	---	---

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2



Page 5
ACI-99

(FL4-C14)

ADAPT-PT V- 7.10

4.2 - Computed Section Properties for Segments of Nonprismatic Spans

Section properties are listed for all segments of each span

A= cross-sectional geometry

Yt= centroidal distance to top fiber

I= gross moment of inertia

Yb= centroidal distance to bottom fiber

SPAN (SEGMENT)	AREA cm ²	I cm ⁴	Yb cm	Yt cm
2	2	3	4	5
SPAN 2				
1	24000.00	.1800E+07	15.00	15.00
2	24000.00	.1800E+07	15.00	15.00
3	36000.00	.6075E+07	22.50	22.50
4	36000.00	.6075E+07	22.50	22.50
CANTILEVER RIGHT				
1	36000.00	.6075E+07	22.50	22.50
2	36000.00	.6075E+07	22.50	22.50
3	24000.00	.1800E+07	15.00	15.00

5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >		
SPAN	M(l)*	Midspan	M(r)*	SH(l)	SH(r)
-1	2	3	4	5	6
1	.00	32.96	-56.71	-25.14	40.26
2	-44.38	17.12	-64.14	-32.81	41.27
CANT	-71.96	-----	-----	-40.34	-----

Note:

* = Centerline moments

JOINT	< 5.3 REACTIONS (T) >	< 5.4 COLUMN MOMENTS (Tm) >
-1	2	3
1	25.14	.00
2	73.08	5.81
3	81.60	-3.75



6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->								
<---- left* ---->			<---- midspan ---->		<---- right* ---->		<--SHEAR FORCE-->	
SPAN	max	min	max	min	max	min	left	right
-1	2	3	4	5	6	7	8	9
1	.00	.00	30.19	-3.20	-52.12	-5.39	-23.05	36.95
2	-41.07	-7.17	17.43	-5.45	-54.98	-3.72	-30.26	33.74



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 6
ACI-99

(FL4-C14)

ADAPT-PT V- 7.10

CR -57.76 ----- -30.40 -----

Note:

* = Centerline moments

<- 6.2 REACTIONS (T) ->			<----- 6.3 COLUMN MOMENTS (Tm) ----->			
			<--- LOWER COLUMN --->		<--- UPPER COLUMN --->	
JOINT	max	min	max	min	max	min
1	24.19	-1.14	.00	.00	.00	.00
2	69.66	28.37	16.04	-10.83	18.00	-12.15
3	66.98	29.82	23.97	-25.30	26.05	-27.50

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases

7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D D E A D L O A D M O M E N T S (Tm)			
SPAN	<- left* ->	<- midspan ->	<- right* ->
1	.00	32.96	-37.66
2	-29.06	17.12	-44.96
CANT	-53.24	-----	-----

Note:

* = face-of-support



7.2 R E D U C E D L I V E L O A D M O M E N T S (Tm)						
SPAN	<----- left* ----->		<----- midspan ----->		<----- right* ----->	
	max	min	max	min	max	min
1	.00	.00	30.19	-3.20	-34.64	-5.03
2	-26.94	-6.96	17.43	-5.45	-39.11	-3.93
CR	-43.56	-----	-----	-----	-----	-----

Note:

* = face-of-support

8 - S U M O F D E A D A N D L I V E M O M E N T S (Tm)

Maxima of dead load and live load span moments combined
for serviceability checks (1.00DL + 1.00LL)

<----- left* -----> <----- midspan -----> <----- right* ----->



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 7
ACI-99

(FL4-C14)

ADAPT-PT V- 7.10

SPAN	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	.00	.00	63.15	29.76	-72.30	-42.69
2	-56.00	-36.02	34.55	11.67	-84.07	-48.90
CR	-96.80					

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:


For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	TENDON	PROFILE			
	TYPE	X1/L	X2/L	X3/L	A/L
	1-----2-----3-----4-----5-----				
1	1	.100	.500	.100	.000
2	1	.100	.500	.100	.000
CANT	1	.100			



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION

SPAN	<----- SELECTED VALUES ----->				<--- CALCULATED VALUES --->		
	FORCE	<- DISTANCE OF CGS (cm) ->			P/A	Wbal	Wbal
	(T/-)	Left	Center	Right	(Kg/cm^2)	(T/-)	(%DL)
-1-----2-----3-----4-----5-----6-----7-----8-----							
1	314.688	-15.00	-24.40	-4.20	13.11	6.624	76
2	434.505	-4.20	-10.40	-4.20	18.10	3.367	36
CANT	420.210	-4.20		-15.00	11.88	6.397	60

Approximate weight of strand 521.4 Kg

9.35 - TENDON SELECTION DATA:

TYPE	SEL.	FORCE (T)	TENDON EXTENTS		
			<1>	<2>	<C>
--1--	2	3	4	5	6
A	26	12.03	=====		
C	10	11.96		=====	

9.5 REQUIRED MINIMUM POST - TENSIONING FORCES (T)

<- BASED ON STRESS CONDITIONS ->				<- BASED ON MINIMUM P/A ->		
SPAN	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
--1--	2	3	4	5	6	7
1	.00	183.73	275.77	240.00	240.00	240.00
2	209.45	.00	20.59	240.00	240.00	360.00
CANT	70.62	-----	-----	360.00	-----	-----

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

LEFT *				RIGHT *			
TOP		BOTTOM		TOP		BOTTOM	
max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
--1--	2	3	4	5	6	7	8
1	-----	-12.91	-----	-12.91	11.29	-13.38	-----
2	11.16	-5.50	-----	-47.79	2.06	-10.97	-----
CR	-----	-16.74	-----	-22.82	-----	-----	-----

Note:

* = face-of-support

CENTER			
TOP		BOTTOM	
max-T	max-C	max-T	max-C
--1--	2	3	4
1	-----	-39.66	13.44
2	-----	-40.58	4.37
CR	-----	-----	-----



9.7 POST-TENSIONING BALANCED MOMENTS, SHEARS & REACTIONS

<-- SPAN MOMENTS (Tm) -->				<-- SPAN SHEARS (T) -->	
SPAN	left*	midspan	right*	SH(l)	SH(r)
--1--	2	3	4	5	6
1	.00	-31.29	36.64	.46	.46
2	20.63	-7.59	46.23	.97	.97
CANT	66.82	-----	-----	20.45	-----



Note:

* = face-of-support

-joint-	<--REACTIONS (T)-->		<-- COLUMN MOMENTS (Tm)-->	
	2		Lower columns	Upper columns
1	.456		.000	.000
2	.511		-9.557	-10.730
3	.967		14.220	15.460

10 - FACTORED MOMENTS & REACTIONS

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

SPAN	<----- left* ----->		<---- midspan ---->		<----- right* ----->	
	max	min	max	min	max	min
-1-----2-----3-----			-4-----5-----		-6-----7-----	
1	.00	.00	96.64	39.88	-113.16	-62.82
2	-108.91	-74.94	27.79	-11.10	-158.63	-98.83
CR	-148.59		-----		-----	

Note:

* = face-of-support

10.2 SECONDARY MOMENTS (Tm)

SPAN	<-- left* -->	<- midspan ->	<-- right* -->
-1-----2-----3-----4-----			
1	.00	-.83	-1.55
2	-22.43	-25.81	-29.20

Note:

* = face-of-support

10.3 FACTORED REACTIONS
(T)

JOINT			10.4 FACTORED COLUMN MOMENTS (Tm)			
	max	min	<-- LOWER column -->	<-- UPPER column -->	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	75.86	32.81	.00	.00	.00	.00
2	220.22	150.03	25.84	-19.84	29.00	-22.26
3	229.07	165.90	49.72	-34.03	54.04	-36.99

11 - M I L D S T E E L

Support cut-off length for minimum steel (length/span)17
Span cut-off length for minimum steel (length/span)33
Top bar extension beyond where required 30.00 cm
Bottom bar extension beyond where required 30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1 TOTAL WEIGHT OF REBAR = 36.1 Kg AVERAGE = .2 Kg/m²
TOTAL AREA COVERED = 154.40 m²

11.2.1 STEEL AT MID-SPAN

SPAN	T O P					B O T T O M				
	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	----	TENS----->			<---ULT---	----	TENS----->	
1	.0	(	.0	.0	.0)	12.4	(	12.4	.0	.0)
2	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.3.1 STEEL AT SUPPORTS

JOINT	T O P					B O T T O M				
	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT---	----	MIN----->			<---ULT---	----	MIN----->	
1	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
2	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]	AREA [cm ²]
1	2	3	4	5	6	7
1	1	B	3 #	6 x	248	8.5
1	2	B	2 #	6 x	172	5.7

Notes:


Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.
Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.


11.5.1 ARRANGEMENT OF TOP BARS

T O P S T E E L					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
1	2	3	4	5	6



11.5.2 ARRANGEMENT OF BOTTOM BARS

BOTTOM STEEL					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
1	1	CENTER	3	# 6 x	247
1	2	CENTER	2	# 6 x	172



12 - PUNCHING SHEAR CHECK

LEGEND:

- CONDITION... 1 = INTERIOR COLUMN
2 = END COLUMN
3 = CORNER COLUMN
4 = EDGE COLUMN (PARALLEL TO SPAN)
5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
PERFORM SHEAR CHECK MANUALLY
6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR

- CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)
2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

FACTORED ACTIONS				<- PUNCHING SHEAR STRESSES IN Kg/cm ² ->					
JNT	COND.	shear T	moment T-m	due to shear	due to moment	TOTAL	allow-able	STRESS RATIO	CASE
1	6								
2	1	220.22	54.84	17.50	4.47	21.97	19.58	1.12	1
3	1	229.07	103.77	10.36	4.21	14.57	19.58	.74	1

PUNCHING SHEAR STRESS IN ONE OR MORE LOCATIONS EXCEEDS THE PERMISSIBLE VALUE. PROVIDE SHEAR REINFORCEMENT, OR ENLARGE THE SECTION RESISTING THE PUNCHING SHEAR

PUNCHING SHEAR CHECK NOT CARRIED OUT FOR SUPPORT WITH CONDITIONS 5 OR 6

13 - MAXIMUM SPAN DEFLECTIONS

Concrete's modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$
Creep factor $K = 2.00$
Ineffective/ I_{gross} ...(due to cracking)..... $K = 1.00$

Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
Values in parentheses are (span/max deflection) ratios



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C


Page 12
ACI-99

(FL4-C14)

ADAPT-PT V- 7.10

<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>

SPAN	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-----2-----3-----4-----5-----6-----					
1	.3	.0	.1 (9238)	.3 (2588)	.4 (2022)
2	.1	.1	.4 (2032)	.1 (7973)	.5 (1619)
CANR	.2	-.3	-.9 (410)	.1 (3256)	-.8 (470)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION
STRUCTURAL CONCRETE SOFTWARE SYSTEM
1733 Woodside Road, Suite 220, Redwood City, California 94061

ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN
Version 7.10 AMERICAN (ACI 318-99/UBC-77)
ADAPT CORPORATION - Structural Concrete Software System
1733 Woodside Road, Suite 220, Redwood City, California 94061
Phone: (650)306-2400, Fax: (650)364-4678
Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 13, 2020 At Time: 12:3
PROJECT FILE: FL4-CE

PROJECT TITLE:
Government Complex
FL4-CE

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS 350.00 Kg/cm²
for COLUMNS 350.00 Kg/cm²

MODULUS OF ELASTICITY for BEAMS/SLABS 287.00 T/cm²
for COLUMNS 287.00 T/cm²

CREEP factor for deflections for BEAMS/SLABS 2.00
CONCRETE WEIGHT NORMAL

SELF WEIGHT 2400.00 Kg/m³

TENSION STRESS limits (multiple of (f'c)^{1/2})
At Top 1.590
At Bottom 1.590

COMPRESSION STRESS limits (multiple of (f'c))
At all locations450

REINFORCEMENT:

YIELD Strength 4.00 T/cm²
Minimum Cover at TOP 1.50 cm
Minimum Cover at BOTTOM 1.50 cm

POST-TENSIONING:

SYSTEM BONDED
Ultimate strength of strand 19.00 T/cm²
Average effective stress in strand (final) 10.80 T/cm²
Strand area990 cm²
Min CGS of tendon from TOP 4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans.. 5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans.. 5.60 cm
Min average precompression 10.00 Kg/cm²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL4-CE)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES

2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S P A N E M	T Y P E	F L O O R	LENGTH m	WIDTH cm	DEPTH cm	TOP FLANGE		BOTTOM/MIDDLE FLANGE		REF HEIGHT cm	MULTIPLIER	
						width	thick.	width	thick.		left	right
						cm	cm	cm	cm			
1	C	U	1	3.55	800.00	30.00				.00	.50	.50
1	U	1	8.40	800.00	30.00					.00	.50	.50
2	U	1	8.00	800.00	30.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line

2.2 - SUPPORT WIDTH AND COLUMN DATA

JOINT	SUPPORT		LOWER COLUMN				UPPER COLUMN			
	WIDTH	LENGTH	B (DIA)	D	CBC*		LENGTH	B (DIA)	D	CBC*
	cm	m	cm	cm			m	cm	cm	
1	80.00	4.30	100.00	80.00	(1)		3.60	100.00	80.00	(1)
2	80.00	4.30	100.00	80.00	(1)		3.60	100.00	80.00	(1)
3	.00	4.30	.00	.00	(2)		3.60	.00	.00	(2)

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3

Fixed at near end, roller with rotational fixity at far end .. = 4



3 - INPUT APPLIED LOADING

<---CLASS---> <-----TYPE----->
D = DEAD LOAD U = UNIFORM P = PARTIAL UNIFORM
L = LIVE LOAD C = CONCENTRATED M = APPLIED MOMENT
Li = LINE LOAD
SW= SELF WEIGHT Computed from geometry input and treated as dead loading
Unit selfweight W = 2400.0 Kg/m³

SPAN	CLASS	TYPE	Intensity T/m^2	(From ... (m	To) m)	(M or C ...At) (T-m or T ...m)	Total on Trib T/m	
-1-	2-	3-	4-	5-	6-	7-	8-	9-
CANT	L	U	1.000	.00	3.55			8.000
CANT	D	U	.370	.00	3.55			2.960
CANT	SW	U		.00	3.55			5.760
1	L	U	1.000	.00	8.40			8.000
1	D	U	.370	.00	8.40			2.960
1	SW	U		.00	8.40			5.760
2	L	U	1.000	.00	8.00			8.000
2	D	U	.370	.00	8.00			2.960
2	SW	U		.00	8.00			5.760

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

			UNIFORM				
			(T/m^2),	(CON. or PART.)	(M O M E N T)		
SPAN	CLASS	TYPE	LINE(T/m)	(T@m or m-m)	(T-m @ m)		
-1-----	2-----	3-----	4-----	5-----	6-----	7-----8-----	
CANT	L	U	1.000				
CANT	D	U	.370				
1	L	U	1.000				
1	D	U	.370				
2	L	U	1.000				
2	D	U	.370				



NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 4
ACI-99

(FL4-CE)

ADAPT-PT V- 7.10

4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA cm ²	I cm ⁴	Yb cm	Yt cm
-1-----2-----3-----4-----5-----				
CANT.	24000.00	.1800E+07	15.00	15.00
1	24000.00	.1800E+07	15.00	15.00
2	24000.00	.1800E+07	15.00	15.00

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2



5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >	
SPAN	M(l)*	Midspan	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----				
CANT	-----	-----	-----	30.96
1	-50.81	23.72	-36.06	37.19
2	-65.39	37.06	-43.05	26.71

Note:

* = Centerline moments

< 5.3 REACTIONS (T) >		< 5.4 COLUMN MOMENTS (Tm) ->	
JOINT		Lower columns	Upper columns
-1-----2-----3-----4-----5-----6-----			
1	67.01	1.95	2.19
2	80.25	-4.62	-5.19
3	26.71	.00	.00

6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->

<----- left* ----->		<----- midspan ----->		<----- right* ----->		<--SHEAR FORCE-->		
SPAN	max	min	max	min	max	min	left	right
-1-----2-----3-----4-----5-----6-----7-----8-----9-----								
CL	-----	-----	-----	-----	-50.41	-----	-----	28.40
1	-46.61	-8.53	24.34	-8.03	-50.99	-7.52	-33.08	34.12
2	-59.99	-7.87	34.00	-4.70	.00	.00	-39.50	24.50

Note:

* = Centerline moments

<- 6.2 REACTIONS (T) ->			<----- 6.3 COLUMN MOMENTS (Tm) ----->			
			<--- LOWER COLUMN --->		<--- UPPER COLUMN --->	
JOINT	max	min	max	min	max	min
--1-----2-----3-----4-----5-----6-----7----						
1	64.17	28.56	18.39	-16.60	20.64	-18.64
2	76.73	32.74	13.40	-17.64	15.04	-19.80
3	26.07	-1.57	.00	.00	.00	.00

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases

7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D DEAD LOAD MOMENTS (Tm)

SPAN	<- left* ->	<- midspan ->	<- right* ->
--1-----2-----3-----4-----			
CANT	-----	-----	-43.26
1	-37.08	23.72	-41.40
2	-48.87	37.06	.00

Note:

* = face-of-support



7.2 R E D U C E D LIVE LOAD MOMENTS (Tm)

<----- left* ----->		<----- midspan ----->		<----- right* ----->		
SPAN	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
CL	-----	-----	-----	-----	-39.69	
1	-34.02	-8.48	24.34	-8.02	-37.98	-7.57
2	-44.83	-7.47	34.00	-4.70	.00	.00

Note:

* = face-of-support

8 - S U M O F DEAD AND LIVE MOMENTS (Tm)

Maxima of dead load and live load span moments combined
for serviceability checks (1.00DL + 1.00LL)

<----- left* ----->		<----- midspan ----->		<----- right* ----->		
SPAN	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7----						



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 6
ACI-99

(FL4-CE)

ADAPT-PT V- 7.10

CL	-----	-----	-----	-----	-82.95	
1	-71.10	-45.56	48.06	15.69	-79.38	-48.97
2	-93.70	-56.34	71.06	32.36	.00	.00

Note:

* = face-of-support

9 - SELECTED POST-TENSIONING FORCES AND TENDON PROFILES

9.1 PROFILE TYPES AND PARAMETERS

LEGEND:


For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	TENDON	PROFILE			
	TYPE	X1/L	X2/L	X3/L	A/L
	1	2	3	4	5
CANT	1			.100	
1	1	.100	.500	.100	.000
2	1	.100	.500	.100	.000



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION

SPAN	FORCE (T/-)	SELECTED VALUES			CALCULATED VALUES		
		DISTANCE OF CGS (cm)			P/A (Kg/cm ²)	Wbal (T/-)	Wbal (%DL)
		Left	Center	Right			
-1	-2	-3	-4	-5	-6	-7	-8
CANT	358.180	-15.00		-4.20	15.24	6.269	72
1	374.486	-4.20	-15.40	-4.20	15.60	4.755	55
2	369.405	-4.20	-24.40	-15.00	15.39	6.834	78

Approximate weight of strand 504.8 Kg

9.35 - TENDON SELECTION DATA:

Page 7
ACI-99

(FL4-CE)

ADAPT-PT V- 7.10

TYPE	SEL.	FORCE	TENDON EXTENTS									
		(T)	<C>	<1>	<2>							
-1-	2-	3-		----	----		----	----		----	----	
B	31	11.95		<=====								

9.5 REQUIRED MINIMUM POST - TENSIONING FORCES (T)

SPAN	<- BASED ON STRESS CONDITIONS ->			<- BASED ON MINIMUM P/A ->		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
-1-	2-	3-	4-	5-	6-	7-
CANT	-----	-----	348.08	-----	-----	240.00
1	295.39	144.98	353.75	240.00	240.00	240.00
2	373.30	255.01	.00	240.00	240.00	240.00

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

	LEFT *				RIGHT *			
	TOP		BOTTOM		TOP		BOTTOM	
	max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
-1-	2-	3-	4-	5-	6-	7-	8-	9-
CL	-----	-----	-----	-----	28.33	-4.74	-----	-58.38
1	22.60	-----	-----	-53.18	26.91	-----	-----	-58.69
2	28.56	-2.57	-----	-60.29	-----	-15.22	-----	-15.22

Note:

* = face-of-support

	CENTER			
	TOP		BOTTOM	
	max-T	max-C	max-T	max-C
-1-	2-	3-	4-	5-
CL	-----	-----	-----	-----
1	-----	-44.64	13.43	-13.54
2	-----	-47.31	16.52	-15.73

9.7 POST-TENSIONING BALANCED MOMENTS, SHEARS & REACTIONS

SPAN	<- SPAN MOMENTS (Tm) ->			<- SPAN SHEARS (T) ->	
	left*	midspan	right*	SH(l)	SH(r)
-1-	2-	3-	4-	5-	6-
CANT	-----	-----	30.92	-----	18.59
1	25.63	-13.21	28.02	-.31	-.31
2	40.39	-32.77	.00	.49	.49

Note:

* = face-of-support



<-- REACTIONS (T) -->		<-- COLUMN MOMENTS (Tm) -->	
joint		Lower columns	Upper columns
1	.315	-5.257	-5.900
2	-.803	6.738	7.563
3	.488	.000	.000

10 - FACTORED MOMENTS & REACTIONS

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

SPAN	<---- left* ---->		<---- midspan ---->		<---- right* ---->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
CL					-128.04	
1	-120.87	-77.45	63.81	8.78	-132.96	-81.26
2	-140.92	-77.41	111.65	45.85	.00	.00

Note:

* = face-of-support

10.2 SECONDARY MOMENTS (Tm)

SPAN	<-- left* -->	<-- midspan -->	<-- right* -->
-1-----2-----3-----4-----			
1	-11.12	-10.78	-10.43
2	3.71	1.95	.00

Note:

* = face-of-support



10.3 FACTORED REACTIONS (T)

JOINT			<-- LOWER column -->		<-- UPPER column -->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	203.22	142.68	28.74	-30.75	32.25	-34.52
2	241.99	167.20	23.05	-29.72	25.87	-33.36
3	82.20	35.22	.00	.00	.00	.00

10.4 FACTORED COLUMN MOMENTS (Tm)

JOINT			<-- LOWER column -->		<-- UPPER column -->	
	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						
1	203.22	142.68	28.74	-30.75	32.25	-34.52
2	241.99	167.20	23.05	-29.72	25.87	-33.36
3	82.20	35.22	.00	.00	.00	.00

11 - MILD STEEL

Support cut-off length for minimum steel(length/span)17

Span cut-off length for minimum steel (length/span)33
Top bar extension beyond where required 30.00 cm
Bottom bar extension beyond where required 30.00 cm

REINFORCEMENT based on NO REDISTRIBUTION of factored moments

11.1 TOTAL WEIGHT OF REBAR = 104.7 Kg AVERAGE = .7 Kg/m²
TOTAL AREA COVERED = 159.60 m²

11.2.1 STEEL AT MID - SPAN

SPAN	T O P					B O T T O M				
	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT	---TENS	---			<---ULT	---TENS	---	
1	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)
2	.0	(	.0	.0	.0)	11.8	(	11.8	.0	.0)

11.3.1 STEEL AT SUPPORTS

JOINT	T O P					B O T T O M				
	As (cm ²)	DIFFERENT REBAR CRITERIA				As (cm ²)	DIFFERENT REBAR CRITERIA			
		<---ULT	---MIN	---			<---ULT	---MIN	---	
1	6.4	(	6.4	.0	.0)	.0	(	.0	.0	.0)
2	25.4	(	25.4	.0	.0)	.0	(	.0	.0	.0)
3	.0	(	.0	.0	.0)	.0	(	.0	.0	.0)

11.2.2 & 11.3.2 LISTING OF THE ENTIRE PROVIDED REBAR

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]	AREA [cm ²]
0	1	T	4 #	5 x	60	8.0
1	2	T	7 #	5 x	142	14.0
1	3	T	6 #	5 x	100	12.0
2	4	B	3 #	6 x	220	8.5
2	5	B	2 #	6 x	180	5.7



Notes:

Bar location - T = Top, B = Bottom.

NUM - Number of bars.

For two-way systems a minimum of 4 bars is specified over the supports.

Refer to tables 11.5.1, 11.5.2 and PTsum graphical display for positioning of bars.

11.5.1 ARRANGEMENT OF TOP BARS

TOP STEEL					
SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]

Page 10
ACI-99

(FL4-CE)

ADAPT-PT V- 7.10

--1--	--2--	--3--	--4--	--5--	--6--
0	1	RIGHT	4 #	5 x	60
1	2	RIGHT	7 #	5 x	72
1	3	RIGHT	6 #	5 x	100
2	2	LEFT	7 #	5 x	70
2	3	LEFT	6 #	5 x	70

11.5.2 ARRANGEMENT OF BOTTOM BARS

SPAN	ID	LOCATION	NUM	BAR	LENGTH [cm]
--1--	--2--	--3--	--4--	--5--	--6--
2	4	CENTER	3 #	6 x	220
2	5	CENTER	2 #	6 x	180



12 - PUNCHING SHEAR CHECK

LEGEND:

- CONDITION... 1 = INTERIOR COLUMN
 2 = END COLUMN
 3 = CORNER COLUMN
 4 = EDGE COLUMN (PARALLEL TO SPAN)
 5 = EDGE BEAM, WALL, OR OTHER NON-CONFORMING GEOMETRY
 PERFORM SHEAR CHECK MANUALLY
 6 = STRIP TOO NARROW TO DEVELOP PUNCHING SHEAR

- CASE..... 1 = STRESS WITHIN SECTION #1 GOVERNS (COL.CAP OR SLAB)
 2 = STRESS WITHIN SECTION #2 GOVERNS (DROP PANEL OR SLAB)

		FACTORED ACTIONS		<- PUNCHING SHEAR STRESSES IN Kg/cm ² ->					
JNT	COND.	shear T	moment T-m	due to shear	due to moment	TOTAL	allow- able	STRESS RATIO	CASE
-1--	-2--	-3--	-4--	-5--	-6--	-7--	-8--	-9--	-10--
1	1	203.22	65.27	16.15	5.23	21.37	18.94	1.13	1
2	1	241.99	63.08	19.23	5.05	24.28	18.94	1.28	1
3	6								

PUNCHING SHEAR STRESS IN ONE OR MORE LOCATIONS EXCEEDS THE PERMISSIBLE VALUE. PROVIDE SHEAR REINFORCEMENT, OR ENLARGE THE SECTION RESISTING THE PUNCHING SHEAR

PUNCHING SHEAR CHECK NOT CARRIED OUT FOR SUPPORT WITH CONDITIONS 5 OR 6



13 - MAXIMUM SPAN DEFLECTIONS

Concrete's modulus of elasticity $E_c = 287.00 \text{ T/cm}^2$
Creep factor $K = 2.00$
Ieffective/Igross... (due to cracking) $K = 1.00$

Where stresses exceed $1.616(f_c')^{1/2}$ cracking of section is allowed for.
Values in parentheses are (span/max deflection) ratios

<.....DEFLECTION ARE ALL IN cm , DOWNWARD POSITIVE.....>					
SPAN	DL	DL+PT	DL+PT+CREEP	LL	DL+PT+LL+CREEP
-1-----	2-----	3-----	4-----	5-----	6-----
CANL	.4	.0	.1 (3529)	.3 (1041)	.4 (803)
1	.2	.1	.3 (2489)	.2 (4980)	.5 (1659)
2	.4	.1	.2 (3929)	.4 (2163)	.6 (1395)





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

ADAPT CORPORATION STRUCTURAL CONCRETE SOFTWARE SYSTEM 1733 Woodside Road, Suite 220, Redwood City, California 94061
ADAPT-PT FOR POST-TENSIONED BEAM/SLAB DESIGN Version 7.10 AMERICAN (ACI 318-99/UBC-77) ADAPT CORPORATION - Structural Concrete Software System 1733 Woodside Road, Suite 220, Redwood City, California 94061 Phone: (650)306-2400, Fax: (650)364-4678 Email: Support@AdaptSoft.com, Web site: http://www.AdaptSoft.com

DATE AND TIME OF PROGRAM EXECUTION: Nov 13, 2020 At Time: 8:35
PROJECT FILE: FL4-CD--8-9

PROJECT TITLE:
Government Complex
FL4-CD--8-9

1 - USER SPECIFIED GENERAL DESIGN PARAMETERS

CONCRETE:

STRENGTH at 28 days, for BEAMS/SLABS	350.00 Kg/cm ²
for COLUMNS	350.00 Kg/cm ²
MODULUS OF ELASTICITY for BEAMS/SLABS	287.00 T/cm ²
for COLUMNS	287.00 T/cm ²
CREEP factor for deflections for BEAMS/SLABS	2.00
CONCRETE WEIGHT	NORMAL
SELF WEIGHT	2400.00 Kg/m ³

TENSION STRESS limits (multiple of (f'c)^{1/2})

At Top	1.590
At Bottom	1.590

COMPRESSION STRESS limits (multiple of (f'c))

At all locations	.450
------------------------	------

REINFORCEMENT:

YIELD Strength	4.00 T/cm ²
Minimum Cover at TOP	1.50 cm
Minimum Cover at BOTTOM	1.50 cm

POST-TENSIONING:

SYSTEM	BONDED
Ultimate strength of strand	19.00 T/cm ²
Average effective stress in strand (final)	10.80 T/cm ²
Strand area.....	.990 cm ²
Min CGS of tendon from TOP.....	4.20 cm
Min CGS of tendon from BOTTOM for INTERIOR spans..	5.60 cm
Min CGS of tendon from BOTTOM for EXTERIOR spans..	5.60 cm
Min average precompression	10.00 Kg/cm ²





รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 2
ACI-99

(FL4-CD--8-9)

ADAPT-PT V- 7.10

Max spacing between strands (factor of slab depth) 8.00
Tendon profile type and support widths..... (see section 9)

ANALYSIS OPTIONS USED:

Structural system(using EQUIVALENT FRAME).... TWO-WAY
Moments REDUCED to face of support YES



2 - INPUT GEOMETRY

2.1.1 PRINCIPAL SPAN DATA OF UNIFORM SPANS

S P A N N E M	T Y P E	F L O O R	L E N G T H m	W I D T H cm	D E P T H cm	T O P F L A N G E		B O T T O M / M I D D L E F L A N G E		R E F H E I G H T cm	M U L T I P L I E R	
						width	thick.	width	thick.		left	right
1	U	1	8.00	800.00	30.00					.00	.50	.50
C	U	1	2.80	800.00	30.00					.00	.50	.50

LEGEND:

1 - SPAN

C = Cantilever

2 - TYPE

U = Uniform; prismatic

N = Nonuniform section

3 - FORM

1 = Rectangular section

2 = T or Inverted L section

3 = I section

4 = Extended T or L section

7 = Joist

8 = Waffle

11 - Top surface to reference line

2.2 - SUPPORT WIDTH AND COLUMN DATA

J O I N T	S U P P O R T		<----- L O W E R C O L U M N ----->				<----- U P P E R C O L U M N ----->			
	W I D T H cm	L E N G T H m	B (D I A) cm	D cm	C B C *		L E N G T H m	B (D I A) cm	D cm	C B C *
1	.00	4.30	.00	.00	(2)		3.60	.00	.00	(2)
2	80.00	4.30	100.00	80.00	(1)		3.60	100.00	80.00	(1)

*THE COLUMN BOUNDARY CONDITION CODES (CBC)

Fixed at both ends ... (STANDARD) = 1

Hinged at near end, fixed at far end = 2

Fixed at near end, hinged at far end = 3

Fixed at near end, roller with rotational fixity at far end .. = 4



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 3
ACI-99

(FL4-CD--8-9)

ADAPT-PT V- 7.10

3 - INPUT APPLIED LOADING

<---CLASS---> <-----TYPE----->
D = DEAD LOAD U = UNIFORM P = PARTIAL UNIFORM
L = LIVE LOAD C = CONCENTRATED M = APPLIED MOMENT
Li = LINE LOAD
SW= SELF WEIGHT Computed from geometry input and treated as dead loading
Unit selfweight W = 2400.0 Kg/m³

SPAN	CLASS	TYPE	Intensity T/m ²	(From ... (m	To) m)	(M or C ...At) (T-m or T ...m)	Total on Trib T/m	
-1-	-2-	-3-	-4-	-5-	-6-	-7-	-8-	-9-
1	L	U	1.000	.00	8.00			8.000
1	D	U	.370	.00	8.00			2.960
1	SW	U		.00	8.00			5.760
CANT	L	U	1.000	.00	2.80			8.000
CANT	D	U	.370	.00	2.80			2.960
CANT	SW	U		.00	2.80			5.760

NOTE: LIVE LOADING is SKIPPED with a skip factor of .75

3.1 - LOADING AS APPEARS IN USER'S INPUT SCREEN PRIOR TO PROCESSING

UNIFORM
(T/m²), (CON. or PART.) (M O M E N T)
SPAN CLASS TYPE LINE(T/m) (T@m or m-m) (T-m @ m)

-1-	-2-	-3-	-4-	-5-	-6-	-7-	-8-
1	L	U	1.000				
1	D	U	.370				
CANT	L	U	1.000				
CANT	D	U	.370				

NOTE: SELFWEIGHT INCLUSION REQUIRED

LIVE LOADING is SKIPPED with a skip factor of .75



4 - CALCULATED SECTION PROPERTIES

4.1 For Uniform Spans and Cantilevers only

SPAN	AREA	I	Yb	Yt
------	------	---	----	----



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 4
ACI-99

(FL4-CD--8-9)

ADAPT-PT V- 7.10

	cm ²	cm ⁴	cm	cm
-1-----2-----3-----4-----5-----				
1	24000.00	.1800E+07	15.00	15.00
CANT.	24000.00	.1800E+07	15.00	15.00

Note:

--- = Span/Cantilever is Nonuniform, see block 4.2



5 - DEAD LOAD MOMENTS, SHEARS & REACTIONS

< 5.1 SPAN MOMENTS (Tm) >			< 5.2 SPAN SHEARS (T) >		
SPAN	M(l)*	Midspan	M(r)*	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----					
1	.00	40.34	-58.85	-27.52	42.24
CANT	-34.18	-----	-----	-24.42	-----

Note:

* = Centerline moments

< 5.3 REACTIONS (T) >		< 5.4 COLUMN MOMENTS (Tm) ->	
JOINT		Lower columns	Upper columns
-1-----2-----3-----4-----5-----6-----7-----8-----9-----			
1	27.52	.00	.00
2	66.65	11.62	13.04

6 - LIVE LOAD MOMENTS, SHEARS & REACTIONS

<-- 6.1 LIVE LOAD SPAN MOMENTS (Tm) and SHEAR FORCES (T) -->								
<---- left* ---->			<---- midspan ---->		<---- right* ---->		<--SHEAR FORCE-->	
SPAN	max	min	max	min	max	min	left	right
-1-----2-----3-----4-----5-----6-----7-----8-----9-----								
1	.00	.00	37.01	-3.60	-53.99	-7.20	-25.25	38.75
CR	-31.36	-----	-----	-----	-----	-----	-22.40	-----

Note:

* = Centerline moments

<-- 6.2 REACTIONS (T) ->		<----- 6.3 COLUMN MOMENTS (Tm) ----->					
		<--- LOWER COLUMN --->		<--- UPPER COLUMN --->			
JOINT	max	min	max	min	max	min	
-1-----2-----3-----4-----5-----6-----7-----8-----9-----							
1	26.45	-1.20	.00	.00	.00	.00	
2	61.15	23.60	20.92	-10.26	23.48	-11.51	



รายงานการออกแบบ Design Note รายการคำนวณงานโครงสร้าง

(สัญญาก่อสร้างอาคารทิศตะวันออก Final Detailed Design)

(ส่วนงานโครงสร้าง งานสถาปัตยกรรม และงานระบบหลัก)

โครงการพัฒนาพื้นที่ส่วนขยายศูนย์ราชการเฉลิมพระเกียรติ ๘๐ พรรษา ๕ ธันวาคม ๒๕๕๐ พื้นที่โซน C

Page 5
ACI-99

(FL4-CD--8-9)

ADAPT-PT V- 7.10

Note: Block 6.1 through 6.3 values are maxima of all skipped loading cases


7 - M O M E N T S REDUCED TO FACE-OF-SUPPORT

7.1 R E D U C E D DEAD LOAD MOMENTS (Tm)

SPAN	<- left* ->	<- midspan ->	<- right* ->
--1-----2-----3-----4-----			
1	.00	40.34	-42.65
CANT	-25.11	-----	-----

Note:

* = face-of-support



7.2 R E D U C E D LIVE LOAD MOMENTS (Tm)

SPAN	<----- left* ----->	<----- midspan ----->	<----- right* ----->
	max min	max min	max min
-1-----2-----3-----4-----5-----6-----7-----			
1	.00 .00	37.01 -3.60	-39.13 -6.84
CR	-23.04	-----	-----

Note:

* = face-of-support

8 - S U M OF DEAD AND LIVE MOMENTS (Tm)

Maxima of dead load and live load span moments combined
for serviceability checks (1.00DL + 1.00LL)

SPAN	<----- left* ----->	<----- midspan ----->	<----- right* ----->
	max min	max min	max min
-1-----2-----3-----4-----5-----6-----7-----			
1	.00 .00	77.35 36.74	-81.78 -49.49
CR	-48.15	-----	-----

Note:

* = face-of-support

9 - S E L E C T E D POST-TENSIONING FORCES AND TENDON PROFILES

9.1 P R O F I L E T Y P E S AND PARAMETERS

LEGEND:

For Span:

- 1 = reversed parabola
- 2 = simple parabola with straight portion over support
- 3 = harped tendon

For Cantilever:

- 1 = simple parabola
- 2 = partial parabola
- 3 = harped tendon

9.2	TENDON		PROFILE		
	TYPE	X1/L	X2/L	X3/L	A/L
	1	2	3	4	5
1	1	.100	.500	.100	.000
CANT	1	.100			



9.3 - SELECTED POST-TENSIONING FORCES AND TENDON DRAPE

Tendon editing mode selected: TENDON SELECTION

SPAN	FORCE (T/-)	SELECTED VALUES			CALCULATED VALUES		
		Left	Center	Right	P/A (Kg/cm ²)	Wbal (T/-)	Wbal (%DL)
1	375.522	-15.00	-24.40	-4.20	15.65	6.947	80
CANT	374.332	-4.20		-15.00	15.48	10.238	117

Approximate weight of strand 293.5 Kg

9.35 - TENDON SELECTION DATA:

TYPE	SEL.	FORCE (T)	TENDON EXTENTS	
			<1>	<C>
B	16	11.79	=====	
C	16	11.64	=====	

9.5 REQUIRED MINIMUM POST-TENSIONING FORCES (T)

SPAN	BASED ON STRESS CONDITIONS			BASED ON MINIMUM P/A		
	LEFT*	CENTER	RIGHT*	LEFT	CENTER	RIGHT
1	.00	309.50	275.82	240.00	240.00	240.00
CANT	96.13	-----	-----	240.00	-----	-----

Note:

* = face-of-support

9.6 SERVICE STRESSES (Kg/cm²) (tension shown positive)

LEFT *				RIGHT *			
TOP		BOTTOM		TOP		BOTTOM	
max-T	max-C	max-T	max-C	max-T	max-C	max-T	max-C
-1-----2-----3-----4-----5-----6-----7-----8-----9-----							
1	-15.66	-15.66	-15.66	16.42	-10.49	-47.38	-47.38
CR	.16	-19.04	-31.01				

Note:

* = face-of-support

CENTER			
TOP		BOTTOM	
max-T	max-C	max-T	max-C
-1-----2-----3-----4-----5-----			
1	-53.64	22.34	-11.49
CR			

9.7 POST-TENSIONING BALANCED MOMENTS, SHEARS & REACTIONS

<-- SPAN MOMENTS (Tm) -->				<-- SPAN SHEARS (T) -->	
SPAN	left*	midspan	right*	SH(l)	SH(r)
-1-----2-----3-----4-----5-----6-----					
1	.00	-31.76	43.50	-.89	-.89
CANT	29.45			24.14	

Note:

* = face-of-support

<-- REACTIONS (T) -->		<-- COLUMN MOMENTS (Tm) -->	
-joint-----2-----		Lower columns-----Upper columns-----	
1	.886	.000	.000
2	-.886	-3.740	-4.197

10 - FACTORED MOMENTS & REACTIONS

=====

Calculated as (1.40D + 1.70L + 1.00 secondary moment effects)

10.1 FACTORED DESIGN MOMENTS (Tm)

<----- left* ----->			<----- midspan ----->		<----- right* ----->	
SPAN	max	min	max	min	max	min
-1-----2-----3-----4-----5-----6-----7-----						